

Addendum/Addenda

No./N°
2

Project Description / Description de projet

M-06 Boiler #1 & Boiler #3 Upgrades

Solicitation No./ N° de sollicitation	Project No./N° de projet	W.O. No./N° d'ordre de travail
15-22191	5042	A1-006911-06-03
Departmental Representative / Représentant Ministériel	Date	
Marco Pozzebon	22 Mar 2016	

Notice:

This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.

Nota:

Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

NRC-CNRC 779 (03-94)
Page 1 of 1

For Clarification

Question:

The location of 4 differential pressure transmitter/switches to monitor the building for negative pressure. It looks like they go through the wall on all four sides of the building. That means long conduit runs. Do you know where these switches will go?

Answer:

As indicated in the contract documents these shall be positioned with one on each building exposure. Assume the outdoor locations shall be at high level, however final location and placement shall be coordinated on site with Departmental Representative and R&R Automation.



National Research
Council Canada

Conseil national de
recherches Canada

Canada