

## Questions and Answers- Amendment 002

Q1) Drawing A300 shows **cement panel** at west soffit, but not seen on soffit Assembly details (6/A600).

Answer: Any reference to cement panel is a typographical error. The details identify metal panel and are to be considered the correct assembly & material for the purposes of bid pricing.

Q2) Is 915mm diameter **concrete drain (drywell)** Precast or Poured? If it's precast, please provide manufacture info.

Answer: A concrete drain is to be used however the specific method of install and/or manufacturer are left to the GC's discretion. The drain must meet the performance requirements identified in the contract documents.