

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 22 - Construction/Demolition Waste Management and Disposal.
- .3 Section 23 05 54 - Mechanical Identification.

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME B40.100-01, Pressure Gauges and Gauge Attachments.
 - .2 ASME B40.200-01, Thermometers, Direct Reading and Remote Reading.
- .2 Canadian General Standards Board (CGSB).
 - .1 CAN/CGSB-14.4-M88, Thermometers, Liquid-in-Glass, Self Indicating, Commercial/Industrial Type.
 - .2 CAN/CGSB-14.5-M88, Thermometers, Bimetallic, Self-Indicating, Commercial/Industrial Type.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawings and product data.
- .3 Submit manufacturer's product data for following items:
 - .1 Thermometers.
 - .2 Pressure gauges.
 - .3 Stop cocks.
 - .4 Syphons.
 - .5 Wells.

1.4 HEALTH AND SAFETY

- .1 Do construction occupational health and safety in accordance with Section 01 35 28 - Health and Safety Requirements.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Environmental and Waste Management Plans.

- .2 Collect, separate and place in designated containers for reuse and recycling paper plastic polystyrene corrugated cardboard packaging Steel Metal Plastic in accordance with Waste Management Plan.
- .3 Fold up metal banding, flatten and place in designated area for recycling.
- .4 Place materials defined as hazardous or toxic waste in designated containers.
- .5 Ensure emptied containers are sealed, labelled and stored safely for disposal away from children.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Design point to be at mid point of scale or range.
- .2 Ranges: as indicated.

2.2 DIRECT READING THERMOMETERS

- .1 Industrial, variable angle type, liquid filled, 125 mm scale length: to CAN/CGSB14.4 ASME B40.200.
 - .1 Acceptable Manufacturer:
 - Trerice
 - Taylor
 - Weiss
 - .2 Thermometer shall read in both °F and °C.

2.3 REMOTE READING THERMOMETERS

- .1 100 mm diameter mercury-free liquid filled vapour activated dial type: to CAN/CGSB-14.5 ASME B40.200, accuracy within one scale division, brass movement, stainless steel capillary, stainless steel spiral armour, stainless steel bulb and polished brass or stainless steel case for wall mounting.
 - .1 Acceptable Manufacturer:
 - Trerice
 - Taylor
 - Weiss
 - .2 Thermometer shall read in both °F and °C.

2.4 THERMOMETER WELLS

- .1 Copper pipe: copper or bronze.
- .2 Steel pipe: brass or stainless steel.

2.5 PRESSURE GAUGES

- .1 112 mm, dial type: to ASME B40.100, Grade 2A, stainless steel bourdon tube having 0.5% accuracy full scale unless otherwise specified.
 - .1 Acceptable Manufacturer:
 - Trerice
 - Taylor
 - Weiss
 - .2 Provide:
 - .1 Snubber for pulsating operation.
 - .2 Diaphragm assembly for corrosive service.
 - .3 Gasketed pressure relief back with solid front.
 - .4 Bronze stop cock.
 - .5 Oil filled.

PART 3 - EXECUTION

3.1 GENERAL

- .1 Install so they can be easily read from floor or platform. If this cannot be accomplished, install remote reading units.
- .2 Install between equipment and first fitting or valve.
- .3 Install engraved lamicoid nameplates identifying system and medium.

3.2 THERMOMETERS

- .1 Install in wells on piping. Provide heat conductive material inside well.
- .2 Install in locations as indicated and on inlet and outlet of:
 - .1 Heat exchangers.
 - .2 Water heating and cooling coils (supply and return piping).
 - .3 Heat Pumps.
 - .4 Supply and return to ground loop circuit.
 - .5 DHW & buffer tanks.
 - .6 Tempered side of tempering valves.
- .3 Install wells as indicated only for balancing purposes.
- .4 Use extensions where thermometers are installed through insulation.

3.3 PRESSURE GAUGES

- .1 Install in following locations:
 - .1 Suction and discharge of pumps.
 - .2 Upstream and downstream of PRV's.
 - .3 Upstream and downstream of programmed water control valves and heating/cooling coil control valves.
 - .4 Inlet and outlet of coils.
 - .5 Inlet and outlet of liquid side of heat exchangers.
 - .6 Outlet of heat pumps.
 - .7 Domestic Water Entrances.

- .2 Install gauge cocks for balancing purposes, elsewhere as indicated.

- .3 Use extensions where pressure gauges are installed through insulation.

3.4 NAMEPLATES

- .1 Install engraved lamicoïd nameplates as specified in Section 23 05 54 - Mechanical Identification, identifying medium.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 22 - Construction/Demolition Waste Management and Disposal.
- .3 Section 01 35 29 - Health and Safety Requirements.
- .4 Section 01 78 00 - Closeout Submittals.
- .5 Section 23 05 01 - Installation of Pipework.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/ American Society of Mechanical Engineers (ASME):
 - .1 ANSI/ASME B1.20.1-1983(R2001), Pipe Threads, General Purpose (Inch).
 - .2 ANSI/ASME B16.18-2001, Cast Copper Alloy Solder Joint Pressure Fittings.
- .2 American Society for Testing and Materials International, (ASTM):
 - .1 ASTM A276-04, Specification for Stainless Steel Bars and Shapes.
 - .2 ASTM B62-02, Specification for Composition Bronze or Ounce Metal Castings.
 - .3 ASTM B283-99a, Specification for Copper and Copper Alloy Die Forgings (Hot-Pressed).
 - .4 ASTM B505/B505M-02, Specification for Copper-Base Alloy Continuous Castings.
- .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS):
 - .1 MSS-SP-25, Standard Marking System for Valves, Fittings, Flanges and Unions.
 - .2 MSS-SP-80, Bronze Gate Globe, Angle and Check Valves.
 - .3 MSS-SP-110, Ball Valves, Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data: Submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 01 33 00 - Submittal Procedures.

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit data for valves specified in this section.
- .3 Closeout Submittals:
 - .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 QUALITY ASSURANCE

- .1 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29 - Health and Safety Requirements.

1.5 DELIVERY STORAGE AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 22 - Construction/Demolition Waste Management and Disposal.
- .2 Collect and separate for disposal paper, plastic, polystyrene and corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.

1.6 MAINTENANCE

- .1 Extra Materials:
 - .1 Furnish following spare parts:
 - .1 Valve seats: one for every 10 valves each size, minimum 1.
 - .2 Discs: one for every 10 valves, each size. Minimum 1.
 - .3 Stem packing: one for every 10 valves, each size. Minimum 1.
 - .4 Valve handles: 2 of each size.
 - .5 Gaskets for flanges: one for every 10 flanged joints.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Valves:
 - .1 Except for specialty valves, to be single manufacturer.
 - .2 All products to have CRN registration numbers.
- .2 End Connections:
 - .1 Connection into adjacent piping/ tubing:

- .1 Steel pipe systems: Screwed ends to ANSI/ASME B1.20.1.
- .2 Copper tube systems: Solder ends to ANSI/ASME B16.18.
- .3 Lockshield Keys:
 - .1 Where lockshield valves are specified, provide 10 keys of each size: malleable iron cadmium plated.
- .4 Check Valves:
 - .1 Requirements common to check valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Connections: screwed with hexagonal shoulders.
 - .2 NPS 2 and under, swing type, bronze disc, Class 125:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
 - .3 Acceptable Manufacturer:
 - Jenkins Fig. 40J2G
 - Crane
 - Red & White
 - .3 NPS 2 and under, swing type, composition disc, Class 200:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc: renewable rotating disc of number 6 composition to suit service conditions, bronze two-piece hinge disc construction.
 - .3 Acceptable Manufacturer:
 - Jenkins Fig. 444GJ
 - Crane
 - Red & White
 - .4 NPS 2 and under, horizontal lift type, composition disc, Class 150:
 - .1 Body: with integral seat, union bonnet ring with hex shoulders, cap.
 - .2 Disc: renewable PTFE no. 6 composition rotating disc in disc holder having guides top and bottom, of bronze to ASTM B62.
 - .3 Acceptable Manufacturer:
 - Jenkins Fig. 117 ATJ
 - Crane
 - .5 NPS 2 and under, vertical lift type, bronze disc, Class 125:
 - .1 Disc: rotating disc having guides top and bottom, disc guides, retaining rings.
 - .2 Acceptable Manufacturer:
 - Jenkins Fig. 119J
 - Crane
 - Red & White

- .5 Silent Check Valves:
 - .1 NPS 2 and under:
 - .2 Body: cast high tensile bronze to ASTM B62 with integral seat.
 - .3 Pressure rating: Class 125.
 - .4 Connections: screwed ends to ANSI B1.20.1 and with hex. shoulders.
 - .5 Disc and seat: renewable rotating disc.
 - .6 Stainless steel spring, heavy duty.
 - .7 Seat: regrindable.

- .6 Ball Valves:
 - .1 NPS 2 and under:
 - .1 Body and cap: cast high tensile bronze to ASTM B62.
 - .2 Pressure rating: Class125 2760-kPa CWP 4140-kPa CWP, 860 kPa steam.
 - .3 Connections: Screwed ends to ANSI B1.20.1 and with hexagonal shoulders solder ends to ANSI.
 - .4 Stem: tamperproof ball drive.
 - .5 Stem packing nut: external to body.
 - .6 Ball and seat: replaceable stainless steel hard chrome solid ball and teflon seats.
 - .7 Stem seal: TFE with external packing nut.
 - .8 Operator: removable lever handle.
 - .9 Acceptable Manufacturer:
 - Jenkins Fig. 201J
 - Crane
 - Red & White

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.
- .2 Remove internal parts before soldering.
- .3 Install valves with unions at each piece of equipment arranged to allow servicing, maintenance, and equipment removal.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 22 - Construction/Demolition and Waste Management and Disposal.

1.2 REFERENCES

- .1 American National Standards Institute/ American Society of Mechanical Engineers (ANSI/ASME):
 - .1 ANSI/ASME B31.1-01, Power Piping, (SI Edition).
- .2 American Society for Testing and Materials (ASTM):
 - .1 ASTM A125-1996, Specification for Steel Springs, Helical, Heat-Treated.
 - .2 ASTM A307-00, Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .3 ASTM A563-00, Specification for Carbon and Alloy Steel Nuts.
- .3 Factory Mutual (FM).
- .4 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS):
 - .1 MSS SP58-1993, Pipe Hangers and Supports - Materials, Design and Manufacture.
 - .2 MSS SP69-1996, Pipe Hangers and Supports - Selection and Application.
 - .3 MSS SP89-1998, Pipe Hangers and Supports - Fabrication and Installation Practices.
- .5 Underwriter's Laboratories of Canada (ULC).

1.3 DESIGN REQUIREMENTS

- .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
- .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP58.
- .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.
- .4 Design hangers and supports to support systems under all conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.

- .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment to be in accordance with MSS SP58.

1.4 SHOP DRAWINGS AND PRODUCT DATA

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawings and product data for following items:
 - .1 Bases, hangers and supports.
 - .2 Connections to equipment and structure.
 - .3 Structural assemblies.

1.5 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.6 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 22 - Construction Demolition Waste Management and Disposal.
- .2 Divert unused metal from landfill to metal recycling facility approved by Departmental Representative.
- .3 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .4 Dispose of corrugated cardboard polystyrene plastic packaging material in appropriate on-site bin for recycling in accordance with site waste management program.

PART 2 - PRODUCTS

2.1 GENERAL

- .1 Fabricate hangers, supports and sway braces in accordance with ANSI B31.1 and MSS SP58.
- .2 Use components for intended design purpose only. Do not use for rigging or erection purposes.

2.2 PIPE HANGERS

- .1 Finishes:
 - .1 Pipe hangers and supports: galvanized painted with zinc-rich paint after manufacture.
 - .2 Use electro-plating galvanizing process hot dipped galvanizing process.

- .3 Ensure steel hangers in contact with copper piping are copper plated epoxy coated.
- .2 Upper attachment structural: Suspension from lower flange of I-Beam.
 - .1 Cold piping NPS 2 maximum: Malleable iron C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip.
 - .1 Rod: 9 mm UL listed 13 mm FM approved.
 - .2 Cold piping NPS 2½ or greater, all hot piping: Malleable iron beam clamp, eye rod, jaws and extension with carbon steel retaining clip, tie rod, nuts and washers, UL listed FM approved to MSS-SP58 and MSS-SP69.
- .3 Upper attachment structural: Suspension from upper flange of I-Beam.
 - .1 Cold piping NPS 2 maximum: Ductile iron top-of-beam C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip, UL listed FM approved to MSS SP69.
 - .2 Cold piping NPS 2½ or greater, all hot piping: Malleable iron top-of-beam jaw-clamp with hooked rod, spring washer, plain washer and nut UL listed FM approved.
- .4 Upper attachment to concrete.
 - .1 Ceiling: Carbon steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6 mm minimum greater than rod diameter.
 - .2 Concrete inserts: wedge shaped body with knockout protector plate UL listed FM approved to MSS SP69.
- .5 Shop and field-fabricated assemblies.
 - .1 Trapeze hanger assemblies.
 - .2 Steel brackets.
- .6 Hanger rods: threaded rod material to MSS SP58.
 - .1 Ensure that hanger rods are subject to tensile loading only.
 - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
 - .3 Do not use 22 mm or 28 mm rod.
- .7 Pipe attachments: material to MSS SP58.
 - .1 Attachments for steel piping: carbon steel black galvanized.
 - .2 Attachments for copper piping: copper plated black steel.
 - .3 Use insulation shields for hot pipework.
 - .4 Oversize pipe hangers and supports.
- .8 Adjustable clevis: material to MSS SP69 UL listed FM approved, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.

- .1 Ensure "U" has hole in bottom for rivetting to insulation shields.
- .9 Yoke style pipe roll: carbon steel yoke, rod and nuts with cast iron roll, to MSS SP69.
- .10 U-bolts: carbon steel to MSS SP69 with 2 nuts at each end to ASTM A563.
 - .1 Finishes for steel pipework: galvanized.
 - .2 Finishes for copper, glass, brass or aluminum pipework: galvanized, with formed portion plastic coated epoxy coated.
- .11 Pipe rollers: cast iron roll and roll stand with carbon steel rod to MSS SP69.

2.3 INSULATION PROTECTION SHIELDS

- .1 Insulated cold piping:
 - .1 64 kg/m³ density insulation plus insulation protection shield to: MSS SP69, galvanized sheet carbon steel. Length designed for maximum 33 m span.
- .2 Insulated hot piping:
 - .1 Curved plate 300 mm long, with edges turned up, welded-in centre plate for pipe sizes NPS 12 and over, carbon steel to comply with MSS SP69.

2.4 EQUIPMENT SUPPORTS

- .1 Fabricate equipment supports not provided by equipment manufacturer from structural grade steel meeting requirements of Section 05 12 23 - Miscellaneous Structural Steel. Submit calculations with shop drawings.

2.5 EQUIPMENT ANCHOR BOLTS AND TEMPLATES

- .1 Provide templates to ensure accurate location of anchor bolts.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install in accordance with manufacturer's instructions and recommendations.
- .2 Vibration Control Devices:
 - .1 Install on piping systems at pumps, boilers, chillers, cooling towers, elsewhere as indicated.

- .3 Clamps on riser piping:
 - .1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.
 - .2 Bolt-tightening torques to be to industry standards.
 - .3 Steel pipes: Install below coupling or shear lugs welded to pipe.
 - .4 Cast iron pipes: Install below joint.

- .4 Clevis plates:
 - .1 Attach to concrete with 4 minimum concrete inserts, one at each corner.

- .5 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.

3.3 HANGER SPACING

- .1 Plumbing piping: most stringent requirements of Canadian Plumbing Code.
- .2 Fire protection: to applicable NFPA-13.
- .3 Gas and fuel oil piping: up to NPS 1/2: every 1.8 m and to CSA B139.
- .4 Copper piping: up to NPS 1/2: every 1.5 m.
- .5 Flexible joint roll groove pipe: in accordance with table below, but not less than one hanger at joints.
- .6 Within 300 mm of each elbow.

Maximum Pipe Size: NPS	Maximum Spacing Steel	Maximum Spacing Copper
up to 1-1/4	2.1 m	1.8 m
1-1/2	2.7 m	2.4 m
2	3.0 m	2.7 m
2-1/2	3.6 m	3.0 m
3	3.6 m	3.0 m
3-1/2	3.9 m	3.3 m
4	4.2 m	3.6 m
5	4.8 m	
6	5.1 m	
8	5.7 m	
10	6.6 m	
12	6.9 m	

- .7 Pipework greater than NPS 12: to MSS SP69.

3.3 HANGER INSTALLATION

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members.

3.4 HORIZONTAL MOVEMENT

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4° from vertical.
- .2 Where horizontal pipe movement is less than 13mm, offset pipe hanger and support so that rod hanger is vertical in the hot position.

3.5 FINAL ADJUSTMENT

- .1 Adjust hangers and supports:
 - .1 Ensure that rod is vertical under operating conditions.
 - .2 Equalize loads.
- .2 Adjustable clevis:
 - .1 Tighten hanger load nut securely to ensure proper hanger performance.
 - .2 Tighten upper nut after adjustment.
- .3 C-clamps:
 - .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.
- .4 Beam clamps:
 - .1 Hammer jaw firmly against underside of beam.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 22 - Construction/Demolition Waste Management and Disposal.

1.2 REFERENCES

- .1 Canadian Gas Association (CGA):
 - .1 CSA/CGA B149.1-00, Natural Gas and Propane Installation Code.
- .2 Canadian General Standards Board (CGSB):
 - .1 CAN/CGSB-1.60-97, Interior Alkyd Gloss Enamel.
 - .2 CAN/CGSB-24.3-92, Identification of Piping Systems.
- .3 National Fire Protection Association:
 - .1 NFPA 13, Installation of Sprinkler Systems.
 - .2 NFPA 14, Standpipe and Systems.

1.3 PRODUCT DATA

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product data to include paint colour chips, other products specified in this section.

1.4 SAMPLES

- .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Samples to include nameplates, labels, tags, lists of proposed legends.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 22 - Construction/Demolition Waste Management and Disposal.
- .2 Dispose of unused paint material at official hazardous material collections site approved by Departmental Representative.
- .3 Do not dispose of unused paint material into sewer system, into streams, lakes, onto ground or in other locations where it will pose health or environmental hazard.

PART 2 - PRODUCTS

2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES

- .1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
- .2 Lettering and numbers to be raised or recessed.
- .3 Information to include, as appropriate:
 - .1 Equipment: Manufacturer's name, model, size, serial number, capacity.
 - .2 Motor: voltage, Hz, phase, power factor, duty, frame size.

2.2 SYSTEM NAMEPLATES

- .1 Colours:
 - .1 Hazardous: red letters, white background.
 - .2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
- .2 Construction:
 - .1 3 mm thick laminated plastic or white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.
- .3 Sizes:
 - .1 Conform to following table:

SIZE # MM	SIZES (MM)	NO. OF LINES	HEIGHT OF LETTERS (MM)
1	10 x 50	1	3
2	13 x 75	1	5
3	13 x 75	2	3
4	20 x 100	1	8
5	20 x 100	2	5
6	20 x 200	1	8
7	25 x 125	1	12
8	25 x 125	2	8
9	35 x 200	1	20

- .2 Use maximum of 25 letters/numbers per line.
- .4 Locations:
 - .1 Terminal cabinets, control panels: Use size # 5.
 - .2 Equipment in Mechanical Rooms: Use size # 9.
- .5 Identification for PWGSC Preventive Maintenance Support System (PMSS):
 - .1 Use arrangement of Main identifier, Source identifier, Destination identifier.

- .2 Equipment in Mechanical Room:
 - .1 Main identifier: Size #9.
 - .2 Source and Destination identifiers: Size #6.
 - .3 Terminal cabinets, control panels: Size #5.
- .3 Equipment elsewhere: Sizes as appropriate.

2.3 EXISTING IDENTIFICATION SYSTEMS

- .1 Apply existing identification system to new work.
- .2 Where existing identification system does not cover for new work, use identification system specified this section.
- .3 Before starting work, obtain written approval of identification system from Engineer.

2.4 PIPING SYSTEMS GOVERNED BY CODES

- .1 Identification:
 - .1 Natural gas: to CSA/CGA B149.1 authority having jurisdiction.
 - .2 Sprinklers: to NFPA 13.
 - .3 Standpipe and hose systems: to NFPA 14.

2.5 IDENTIFICATION OF PIPING SYSTEMS

- .1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.
- .2 Pictograms:
 - .1 Where required, to Workplace Hazardous Materials Information System (WHMIS) regulations.
- .3 Legend:
 - .1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.
- .4 Arrows showing direction of flow:
 - .1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.
 - .2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.
 - .3 Use double-headed arrows where flow is reversible.
- .5 Extent of background colour marking:
 - .1 To full circumference of pipe or insulation.
 - .2 Length to accommodate pictogram, full length of legend and arrows.

- .6 Materials for background colour marking, legend, arrows:
 - .1 Pipes and tubing 20 mm and smaller: Waterproof and heat-resistant pressure sensitive plastic marker tags.
 - .2 All other pipes: Pressure sensitive plastic-coated cloth vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100%RH and continuous operating temperature of 150°C and intermittent temperature of 200oC.

- .7 Colours and Legends:
 - .1 Where not listed, obtain direction from Engineer Consultant.
 - .2 Colours for legends, arrows: To following table:

BACKGROUND COLOUR:	LEGEND, ARROWS:
Yellow	BLACK
Green	WHITE
Red	WHITE

.3

Background colour marking and legends for piping systems:

Contents	Background colour marking	Legend
** Add design temperature		
++ Add design temperature and pressure		
Non-Potable Water	Purple	NP Water
Heat Pump Supply	Yellow	Heat Pump
Heat Pump Return	Yellow	Heat Pump
Hot Water Heating Supply	Yellow	Heating Return
Domestic Hot Water Supply	Green	Dom. HW Supply
Dom. HWS Recirculation	Green	Dom. HW Circ.
Domestic Cold Water Supply	Green	Dom. CWS
Storm Water	Green	Storm
Sanitary	Green	SAN
Plumbing Vent	Green	San. Vent
Waste Water	Green	Waste Water
Rain Water Supply	Green	Rain Water
Rain Water Return	Green	Rain Water
Propane Gas	To Codes	

Contents	Background colour marking	Legend
** Add design temperature		
++ Add design temperature and pressure		
Gas Regulator Vents	To Codes	
Fire Protection Water	Red	FIRE PROT. WTR
Sprinklers	Red	SPRINKLERS
Instrument air	Green	INSTRUMENT AIR

2.6 IDENTIFICATION DUCTWORK SYSTEMS

- .1 50 mm high stenciled letters and directional arrows 150 mm long x 50 mm high.
- .2 Colours: Black, or co-ordinated with base colour to ensure strong contrast.

2.7 VALVES, CONTROLLERS

- .1 Brass tags with 12 mm stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

2.8 CONTROLS COMPONENTS IDENTIFICATION

- .1 Identify all systems, equipment, components controls, sensors with system nameplates specified in this section.
- .2 Inscriptions to include function and (where appropriate) fail-safe position.

2.9 LANGUAGE

- .1 Identification to be in English and French.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.

- .2 Provide ULC and or CSA registration plates as required by respective agency.
- .3 Identify systems, equipment to conform to PWGSC PMSS.

3.2 NAMEPLATES

- .1 Locations:
 - .1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:
 - .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:
 - .1 Do not paint, insulate or cover in any way.

3.3 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: At not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.
- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, dampers, etc. Where this is not possible, place identification as close as possible, preferably on upstream side.
- .9 Identification to be easily and accurately readable from usual operating areas and from access points.

- .1 Position of identification to be approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.

3.4 VALVES, CONTROLLERS

- .1 Valves and operating controllers, except at plumbing fixtures, radiation, or where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
- .2 Install one copy of flow diagrams, valve schedules mounted in frame behind non-glare glass where directed by Departmental Representative. Provide one copy (reduced in size if required) in each operating and maintenance manual.
- .3 Number valves in each system consecutively.

END OF SECTION

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society for Testing and Materials:
 - .1 ASTM E202, Test Methods for Analysis of Ethylene Glycols and Propylene Glycols.

1.2 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 22 - Construction/Demolition Waste Management and Disposal.
- .2 Dispose of unused cleaning solutions at official hazardous material collections site approved by the Departmental Representative.
- .3 Do not dispose of unused cleaning solutions into sewer system, into streams, lakes, onto ground or in other locations where it will pose health or environmental hazard.
- .4 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .5 Dispose of corrugated cardboard polystyrene plastic packaging material in appropriate on-site bin for recycling in accordance with site waste management program.

PART 2 - PRODUCTS

2.1 CLEANING SOLUTIONS

- .1 Tri-sodium phosphate: 0.40 kg per 100 L water in system.
- .2 Sodium carbonate: 0.40 kg per 100 L water in system.
- .3 Low-foaming detergent: 0.01 kg per 100 L water in system.

PART 3 - EXECUTION

3.1 CLEANING HYDRONIC AND STEAM SYSTEMS

- .1 Timing:
 - .1 Systems to be operational, hydrostatically tested and with safety devices functional, before cleaning is carried out.

- .2 Cleaning Agency:
 - .1 Retain qualified water treatment specialist to perform system cleaning.

- .3 Install instrumentation such as flow meters, orifice plates, pitot tubes, flow metering valves only after cleaning is certified as complete by water treatment specialist.

- .4 Cleaning procedures:
 - .1 Provide detailed report outlining proposed cleaning procedures at least 4 weeks prior to proposed starting date. Report to include:
 - .1 Cleaning procedures, flow rates, elapsed time.
 - .2 Chemicals and concentrations to be used.
 - .3 Inhibitors and concentrations.
 - .4 Specific requirements for completion of work.
 - .5 Special precautions for protecting piping system materials and components.
 - .6 Complete analysis of water to be used to ensure water will not damage systems or equipment.

- .5 Conditions at time of cleaning of systems:
 - .1 Systems to be free from construction debris, dirt and other foreign material.
 - .2 Control valves to be operational, fully open to ensure that terminal units can be cleaned properly.
 - .3 Strainers to be clean prior to initial fill.
 - .4 Install temporary filters on pumps not equipped with permanent filters.
 - .5 Install pressure gauges on strainers to detect plugging.

- .6 Report on Completion of Cleaning
 - .1 When cleaning is completed, submit report, complete with certificate of compliance with specifications of cleaning component supplier.

- .7 Hydronic Systems:
 - .1 Fill system with water, ensure air is vented from system.
 - .2 Ensure expansion tanks are properly pressurized.
 - .3 Use water meter to record volume of water in system to +/- 0.5%.
 - .4 Add chemicals under direct supervision of chemical treatment supplier.
 - .5 Closed loop systems: circulate system cleaner at 60oC for at least 36 h. Drain as quickly as possible. Refill with water and inhibitors. Test concentrations and adjust to recommended levels.
 - .6 Flush velocity in system mains and branches so as to ensure removal of debris. System pumps may be used for circulating cleaning solution provided that velocities are adequate.
 - .7 Add chemical solution to system.

- .8 Establish circulation, raise temperature slowly to maximum design. Circulate for 12h, ensuring flow in all circuits. Remove heat, continue to circulate until temperature is below 38°C. Drain as quickly as possible. Refill with clean water. Circulate for 6 h at design temperature. Drain and repeat procedures specified above. Flush through low point drains in system. Refill with clean water adding to sodium sulphite (test for residual sulphite).

- .8 Glycol Systems:
 - .1 In addition to procedures specified above perform procedures specified herein.
 - .2 Test to prove concentration will prevent freezing to minus 40°C Test inhibitor strength and include in procedural report. Refer to ASTM E202.

3.2 START-UP OF HYDRONIC SYSTEMS

- .1 After cleaning is completed and system is filled:
 - .1 Establish circulation and expansion tank level, set pressure controls.
 - .2 Ensure air is removed.
 - .3 Check pumps to be free from air, debris, possibility of cavitation when system is at design temperature.
 - .4 Dismantle system pumps used for cleaning, inspect, replace worn parts, install new gaskets and new set of seals.
 - .5 Clean out strainers repeatedly until system is clean.
 - .6 Check water level in expansion tank with cold water with circulating pumps OFF and again with pumps ON.
 - .7 Repeat with water at design temperature.
 - .8 Check pressurization to ensure proper operation and to prevent water hammer, flashing, cavitation. Eliminate water hammer and other noises.
 - .9 Bring system up to design temperature and pressure over a 48 hour period.
 - .10 Adjust pipe supports, hangers, springs as necessary.
 - .11 Monitor pipe movement, performance of expansion joints, loops, guides, anchors.
 - .12 If bellows type expansion joints flex incorrectly, shut down system, re-align, repeat start-up procedures.
 - .13 Re-tighten bolts, etc. using torque wrench, to compensate for heat-caused relaxation. Repeat several times during Commissioning.
 - .14 Check operation of drain valves.
 - .15 Adjust valve stem packings as systems settle down.
 - .16 Fully open all balancing valves (except those that are factory-set).
 - .17 Check operation of over-temperature protection devices on circulating pumps.

- .18 Adjust alignment of piping at pumps to ensure flexibility, adequacy of pipe movement, absence of noise or vibration transmission.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Related Sections:
 - .1 Section 01 33 00 - Submittal Procedures. Section 01 74 19 - Environmental and Waste Management Plans.
 - .2 Section 01 78 00 - Closeout Submittals.
 - .3 Section 23 05 01 - Installation of P Pipework.
 - .4 Section 23 08 01 - Performance Verification of Mechanical Piping Systems.
 - .5 Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems.

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME):
 - .1 ASME B16.5-03, Pipe Flanges and Flanged Fittings.
 - .2 ASME B16.18-01, Cast Copper Alloy Solder Joint Pressure Fittings.
 - .3 ASME B16.22-01, Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings.
 - .4 ASME B18.2.1-96, Square and Hex Bolts and Screws Inch Series.
- .2 American Society for Testing and Materials International (ASTM):
 - .1 ASTM A47/A47M-99 (2004), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A53/A53M-04, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated, Welded and Seamless.
 - .3 ASTM B75M-99, Standard Specification for Seamless Copper Tube Metric.
 - .4 ASTM B837-01, Standard Specification for Seamless Copper Tube for Natural Gas and Liquefied Petroleum (LP) Gas Fuel Distribution Systems.
- .3 Canadian Standards Association (CSA International):
 - .1 CSA W47.1-03, Certification of Companies for Fusion Welding of Steel.
- .4 Canadian Standards Association (CSA)/Canadian Gas Association (CGA):
 - .1 CAN/CSA B149.1HB-00, Natural Gas and Propane Installation Code Handbook.
 - .2 CAN/CSA B149.2-00, Propane Storage and Handling Code.

- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS):
 - .1 Material Safety Data Sheets (MSD)

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet for piping, fittings and equipment.
 - .2 Indicate on manufacturer's catalogue literature following: valves.
 - .3 Indicate VOC's for adhesive and solvents during application and curing.
- .3 Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Closeout Submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 QUALITY ASSURANCE

- .1 Pre-Installation Meeting:
 - .1 Convene pre-installation meeting one week prior to beginning work of this Section and on-site installations.
 - .1 Verify project requirements.
 - .2 Review installation and substrate conditions.
 - .3 Co-ordination with other building subtrades.
 - .4 Review manufacturer's installation instructions and warranty requirements.

- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 28 - Health and Safety Requirements.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Environmental and Waste Management Plans.
 - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
 - .3 Collect and separate for disposal paper plastic polystyrene corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan (WMP).
 - .4 Separate for reuse and recycling and place in designated containers Steel Metal Plastic waste in accordance with Waste Management Plan (WMP).
 - .5 Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Materials and products in accordance with Section 01 00 00 - General Requirements.

2.2 PIPE

- .1 Steel pipe: to ASTM A53/A53M, Schedule 40, seamless as follows:
 - .1 NPS 1/2 to 2, screwed.
 - .2 NPS2 1/2 and over, plain end.
- .2 Copper tube: to ASTM B837.

2.3 JOINTING MATERIAL

- .1 Screwed fittings: pulverized lead paste.
- .2 Welded fittings: to CSA W47.1.
- .3 Flange gaskets: nonmetallic flat.

.4 Brazing: to ASTM B837.

2.4 FITTINGS

- .1 Steel pipe fittings, screwed, flanged or welded:
 - .1 Malleable iron: screwed, banded, Class 150.
 - .2 Steel pipe flanges and flanged fittings: to ASME B16.5.
 - .3 Welding: butt-welding fittings.
 - .4 Unions: malleable iron, brass to iron, ground seat, to ASTM A47/A47M.
 - .5 Bolts and nuts: to ASME B18.2.1.
 - .6 Nipples: schedule 40, to ASTM A53/A53M.
- .2 Copper pipe fittings, screwed, flanged or soldered:
 - .1 Cast copper fittings: to ASME B16.18.
 - .2 Wrought copper fittings: to ASME B16.22.

2.5 VALVES

- .1 Provincial Code approved, lubricated plug ball type.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 PIPING

- .1 Install in accordance with Section 23 05 01 - Installation of Pipework, applicable Provincial/Territorial Codes, CAN/CSA B149.1, CAN/CSA B149.2, supplemented as specified.
- .2 Install drip points:
 - .1 At low points in piping system.
 - .2 At connections to equipment.

3.3 VALVES

- .1 Install valves with stems upright or horizontal unless otherwise approved by Consultant.
- .2 Install valves at branch take-offs to isolate pieces of equipment, and as indicated.

3.3 FIELD QUALITY CONTROL

- .1 Site Tests/Inspection:
 - .1 Test system in accordance with CAN/CSA B149.1 CAN/CSA B149.2 and requirements of authorities having jurisdiction.
- .2 Manufacturer's Field Services:
 - .1 Have manufacturer of products supplied under this Section review work involved in handling, installation/application, protection and cleaning of its products, and submit written reports, in acceptable format, to verify compliance of work with Contract.
 - .2 Provide manufacturer's field services, consisting of product use recommendations and periodic site visits for inspection of product installation, in accordance with manufacturer's instructions.
 - .3 Schedule site visits to review work at stages listed:
 - .1 After delivery and storage of products, and when preparatory work on which work of this Section depends is complete, but before installation begins.
 - .2 Twice during progress of work at 25% and 60% complete.
 - .3 Upon completion of work, after cleaning is carried out.
- .3 Obtain reports within 3 days of review and submit immediately to Departmental Representative.
- .4 Performance Verification:
 - .1 Refer to Section 23 08 01 - Performance Verification of Mechanical Piping Systems.

3.4 ADJUSTING

- .1 Purging: purge after pressure test in accordance with CAN/CSA B149.1 CAN/CSA B149.2.
- .2 Pre-Start-Up Inspections:
 - .1 Check vents from regulators, control valves, terminate outside building in approved location, protected against blockage, damage.
 - .2 Check gas trains, entire installation is approved by authority having jurisdiction.

3.5 CLEANING

- .1 Cleaning: in accordance with Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems CAN/CSA B149.1, CAN/CSA B149.2, supplemented as specified.
- .2 Perform cleaning operations as specified in Section and in accordance with manufacturer's recommendations.
- .3 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 35 29 - Health and Safety Requirements.
- .3 Section 01 74 22 - Construction /Demolition Waste Management & Disposal
- .4 Section 01 77 00 - Closeout Submittals.
- .5 Section 01 91 13 - General Commissioning Requirements.

1.2 REFERENCES

- .1 American Society of Heating Refrigeration and Air-Conditioning Consultants (ASHRAE).
 - .1 Standard 90.1-2001 Energy Standard for Buildings Except Low-Rise Residential Buildings.
- .2 Electrical Equipment Manufacturers Advisory Council (EEMAC).
- .3 Canadian Standards Association (CSA International).
 - .1 CAN/CSA-B214-01, Installation Code for Hydronic Heating Systems.
- .4 National Electrical Manufacturers Association (NEMA).
 - .1 NEMA MG 1-2003, Motors and Generators.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Submit manufacturer's detailed composite wiring diagrams for control systems showing factory installed wiring and equipment on packaged equipment or required for controlling devices or ancillaries, accessories and controllers.
- .4 Submit product data of pump curves for review showing point of operation.
- .5 Indicate piping, valves and fittings shipped loose by packaged equipment supplier, showing their final location in field assembly.
- .6 Provide maintenance data for incorporation into manual specified in Section 01 77 00 - Closeout Submittals.

1.4 HEALTH AND SAFETY

- .1 Do construction occupational health and safety in accordance with Section 01 35 29 - Health and Safety Requirements.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 22 - Construction /Demolition Waste Management & Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene and corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Separate for reuse and recycling and place in designated containers Steel Metal Plastic waste in accordance with Waste Management Plan.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

1.6 EXTRA MATERIALS

- .1 Provide maintenance materials in accordance with Section 01 77 00 - Closeout Submittals.

PART 2 - PRODUCTS

2.1 EQUIPMENT

- .1 Do component selection and sizing to:
 - .1 CAN/CSA-B214.

2.2 IN-LINE CIRCULATORS

- .1 Volute: cast iron, with screwed or flanged design suction and discharge connections.
- .2 Impeller: non-metallic.
- .3 Shaft: ceramic with carbon bearings, EPDM gaskets and o-ring.
- .4 Seal assembly: no mechanical seal. Cartridge type.
- .5 Motor: permanent split capacitor.
- .6 Capacity: as indicated on drawings.

.7 Design pressure: 860kPa.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Do Work in accordance with CAN/CSA-B214.
- .2 In line circulators: install as indicated by flow arrows. Support at inlet and outlet flanges or unions. Install with bearing lubrication points accessible.
- .3 Ensure that pump body does not support piping or equipment. Provide stanchions or hangers for this purpose. Refer to manufacturer's installation instructions for details.
- .4 Install volute venting pet cock in accessible location.
- .5 Check rotation prior to start-up.
- .6 Install pressure gauge test cocks.

3.2 START-UP

- .1 General:
 - .1 In accordance with Section 01 91 13 - General Commissioning Requirements; supplemented as specified herein.
 - .2 In accordance with manufacturer's recommendations.
- .2 Procedures:
 - .1 Before starting pump, check that cooling water system over-temperature and other protective devices are installed and operative.
 - .2 After starting pump, check for proper, safe operation.
 - .3 Check installation, operation of mechanical seals, packing gland type seals. Adjust as necessary.
 - .4 Check base for free-floating, no obstructions under base.
 - .5 Run-in pumps for 12 continuous hours.
 - .6 Verify operation of over-temperature and other protective devices under low- and no-flow condition.
 - .7 Eliminate air from scroll casing.
 - .8 Adjust water flow rate through water-cooled bearings.
 - .9 Adjust flow rate from pump shaft stuffing boxes to manufacturer's recommendation.
 - .10 Adjust alignment of piping and conduit to ensure true flexibility at all times.
 - .11 Eliminate cavitation, flashing and air entrainment.
 - .12 Adjust pump shaft seals, stuffing boxes, glands.
 - .13 Measure pressure drop across strainer when clean and with flow rates as finally set.

- .14 Replace seals if pump used to degrease system or if pump used for temporary heat.
- .15 Verify lubricating oil levels.

3.2 PERFORMANCE VERIFICATION (PV)

- .1 General:
 - .1 In accordance with Section 01 91 13 - General Commissioning Requirements, supplemented as specified herein.
 - .2 In accordance with manufacturer's recommendations.
- .2 Exclusions:
 - .1 This paragraph does not apply to small in-line circulators.
- .3 Assumptions: these PV procedures assume that:
 - .1 Manufacturer's performance curves are accurate.
 - .2 Valves on pump suction and discharge provide tight shut-off.
- .4 Net Positive Suction Head (NPSH):
 - .1 Application: measure NPSH for pumps which operate on open systems and with water at elevated temperatures.
 - .2 Measure using procedures prescribed in the Standard.
 - .3 Where procedures do not exist, discontinue PV, report to Consultant and await instructions.
- .5 Multiple Pump Installations - Series and Parallel:
 - .1 Repeat PV procedures specified above for pump performance and pump BHP for combinations of pump operations.
- .6 Mark points of design and actual performance at design conditions as finally set upon completion of TAB.
- .7 Commissioning Reports: In accordance with Section 01 91 13 - General Commissioning Requirements reports supplemented as specified herein. Reports to include:
 - .1 Record of point(s) of actual performance at maximum and minimum conditions and for single and parallel operation as finally set at completion of commissioning on pump curves.
 - .2 Report forms as specified Section 01 91 13 - General Commissioning Requirements.
 - .3 Pump performance curves (family of curves).

END OF SECTION