

**PART 1**      **GENERAL**

**1.1**      **RELATED SECTIONS**

- .1      Section 01 33 00 - Submittal Procedures.
- .2      Section 26 05 00 – Common Work Requirements - Electrical.

**PART 2**      **PRODUCTS**

**2.1**      **DISCONNECT SWITCHES**

- .1      Fusible and non-fusible, disconnect switch in CSA Enclosure type 1, size as indicated.
- .2      Provision for padlocking in on-off switch position by three locks.
- .3      Mechanically interlocked door to prevent opening when handle in ON position.
- .4      Quick-make, quick-break action.
- .5      ON-OFF switch position indication on switch enclosure cover.
- .6      Heavy-duty rated.
- .7      EEMAC 4X for exterior use and EEMAC 2 for interior use.

**2.2**      **EQUIPMENT IDENTIFICATION**

- .1      Provide equipment identification in accordance with Section 26 05 00 – Common Work Requirements - Electrical.
- .2      Indicate name of load controlled on size 4 nameplate.

**PART 3**      **EXECUTION**

**3.1**      **INSTALLATION**

- .1      Install disconnect switches complete with fuses as indicated.

**END OF SECTION**