

PART 1 GENERAL

1.1 Summary

- .1 This Section defines correction to maximum dry density to take into account aggregate particles larger than 4.75 mm.

1.2 References

- .1 American Society for Testing and Materials (ASTM)
 - .1 ASTM C127-88, Standard Test Method for Specific Gravity and Absorption of Coarse Aggregate.
 - .2 ASTM D698, Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft³) (600kN-m/m³).
 - .3 ASTM D1557, Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft³).
 - .4 ASTM D4253, Standard Test Methods for Maximum Index Density and Unit Weight of Soils Using a Vibratory Table.

1.3 Definitions

- .1 Corrected maximum dry density is defined as:
 - .1 $D = (D1 \times D2) / (F1 \times D2 + F2 \times D1)$
 - .2 Where: D = corrected maximum dry density kg/m³.
 - .1 F1 = fraction (decimal) of total field sample passing 4.75 mm sieve.
 - .2 F2 = fraction (decimal) of total field sample retained on 4.75 mm sieve (equal to 1.00 - F1)
 - .3 D1 = maximum dry density, kg/m³ of material passing 4.75 mm sieve determined in accordance with Method A C of ASTM D698.
 - .4 D2 = bulk density, kg/m³, of material retained on 4.75 mm sieve, equal to 1000G where G is bulk specific gravity (dry basis) of material when tested to ASTM C127.
 - .3 For free draining aggregates, determine D1 (maximum dry density) to ASTM D4253, dry method when directed by Departmental Representative.

PART 2 PRODUCTS (NOT APPLICABLE)

PART 3 EXECUTION (NOT APPLICABLE)

END OF SECTION