



Addendum / Addenda

No./N^o
2

Project Description / Description de projet HFX - Nitrogen Generation System		
Solicitation No./ No de sollicitation 15-22193	Project No./N ^o de projet HFX-5142	W.O. No./N ^o d'ordre de travail
Project Engineer / Ingénieur de projet Nadine Merkley		Date April 6 th , 2016
<p>Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p>Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

Attached Addendum #2

PROJECT: NRC Nitrogen Generation System (Solicitation 15-22193)
PROJECT #: HFX-5142
ISSUED BY: Stantec
DATE: April 06, 2016

The following items and clarifications, additions, changes or modifications to contract documents and are being issued as an Addendum to form part of the contract.

1.0 Specification Items

1) Reference Specification 22 15 00, paragraph 3.3.3

Delete reference to quick couplers and pressure gauges on drop pipes.

2) Reference Specification 22 15 00, paragraph 3.3.7

Locations of traps as defined in specification section 22 15 00

3) Reference Specification 22 15 00, paragraph 3.3.9

Location of traps as defined in specification section 22 15 00

4) Reference Specification 43 00 01, paragraph 2.2.1 and 2.2.2

Kaeser Compressor and air dryers are acceptable alternate products as long as they meet the specifications and capacities identified in contract documents. Prior to final acceptance during shop drawing review the name and contact of local service provide will be required.

---- END OF ADDENDUM ----