



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
PWGSC/TPSGC Acquisitions
1045 Main Street
1st Floor, Lobby C
Unit 108
Moncton, NB E1C 1H1
Bid Fax: (506) 851-6759

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
NB / PEI Division - Moncton Acquisitions Office
1045 Main Street
1st Floor, Lobby C
Unit 108
Moncton, NB E1C 1H1

Title - Sujet Electrical Supplies	
Solicitation No. - N° de l'invitation 5P131-151008/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client 5P131-151008	Date 2016-04-12
GETS Reference No. - N° de référence de SEAG PW-\$MCT-011-5156	
File No. - N° de dossier MCT-5-38122 (011)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-05-16	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Sharpe, Charlene A.	Buyer Id - Id de l'acheteur mct011
Telephone No. - N° de téléphone (506) 851-3467 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation Amendment

Title: Electrical Supplies

Solicitation Amendment No. **001**

This solicitation is hereby amended to provide the following questions and answers:

Q1. Items # 1.1, 1.2, 1.3, can we confirm they require 2 conductors?

A1. All require 3 conductors.

Q2. Item # 1.10, 1.11, 1.12, we need to know the manufacturer required and if they are push on or bolt on?

A2. All require Eaton, bolt-on.

Q3. Item # 1.13, we need more description, we need to know the number of lugs required etc. or manufacturer and part number. Will they accept an enclosure with lugs as a separate item?

A3. Yes, lugs are provided as a separate item.

Revise Item 1.13 to read:

36" x 24" x 8" Type 1 Enclosure from 16 gauge steel with bolted cover and ground connection. Separate lugs: 18 pcs - open power distribution blocks, wire range 2/0-#14, three pole one opening per pole. 185 amp CSA rated. Dimensions: Height=75 mm, Width=45 mm, Depth=50 mm.

Q4. Item # 1.14 and 2.5, we need to know the color of the jacket on the wire?

A4. For 1.14: 50 meters of white and 50 meters of black. For 2.5: 25 meters of white and 25 meters of black.

Q5. Item # 2.2, we need more description, we need to know the number of lugs required etc. or manufacturer and part number. Will they accept an enclosure with lugs as a separate item?

A5. Yes, lugs are provided as a separate item.

Revise Item 2.2 to read:

Junction boxes, CSA type c/w tamper proof screws. 3R painted steel galvanized. Width=8", Height=12", Depth=4". Formed and spot-welded from 16 or 14 gauge galvanized steel. Drip-shield top and seam-free sides, front and back. Slip-on removable cover fastened with plated steel screws. Door handles on body type C enclosures. Embossed mounting holes on back of enclosure. Easily removed knockouts on bottom of enclosure. Separate lugs: 34 pcs - open power distribution blocks, wire range 2/0-#14 two pole one opening per pole. 185 amp CSA rated.

Solicitation No. - N° de l'invitation
5P131-151008/A
Client Ref. No. - N° de réf. du client
5P131-151008

Amd. No. - N° de la modif.
001
File No. - N° du dossier
MCT-5-38122

Buyer ID - Id de l'acheteur
mct011
CCC No./N° CCC - FMS No./N° VME

Dimensions: Height=75 mm, Width=45 mm, Depth=50 mm.
16 pcs - open power distribution blocks, wire range 2/0-#14 single
primary two poles secondary. 185 amp CSA rated.
Dimensions: Height=75 mm, Width=45 mm, Depth=50 mm.

AND

- (1) Reference: **Annex A, List of Materials / Basis of Payment**

DELETE Description for item 2.1; and

INSERT revised Description for item 2.1 as follows:

Recreational vehicle load centres, c/w 1-30 amp 125v
and 1-20 amp 125v receptacle

Provide electrical power to individual recreational
vehicle park sites. Each receptacle protected by
appropriate circuit breaker. 10, 000 RMS
Symmetrical Ampere short circuit current rating. All
receptacles and circuit breakers included. Lugs to
loop through neutral 2/0 - #6. **Load centres must
have both breakers on a common busbar..**

- (2) Reference: **Annex A, List of Materials / Basis of Payment**

DELETE Annex A, List of Materials / Basis of Payment in its entirety; and

INSERT Annex A, List of Materials / Basis of Payment (**revised April 12, 2016**) attached.

If your bid has already been forwarded and you wish to revise same, this revision should be sent either in a sealed envelope and mailed to the above address or by facsimile (506) 851-6759 and reach the undersigned before the appropriate closing date. The solicitation number and the closing date are to be shown on the outside of the sealed envelope or on the facsimile transmission.

All other terms and conditions of the solicitation document remain unchanged.

All enquiries concerning this amendment are to be forwarded to:

Name Charlene Sharpe
Telephone No.: (506) 851-3467
Facsimile No: (506) 851-6759

(Derived from - Provenant de: XNB025D, 23/01/2008)

ANNEX A – LIST OF MATERIALS / BASIS OF PAYMENT
(Revised April 12, 2016)

1. Power Feed Materials						
Item No.	Description	OEM Brand Name and Model Number	Unit of issue	Quantity	Unit Price	Extended price
1.1	2-#1+Gnd Teck 90 Armored Cable, requires 3 conductors		M	316	\$ _____	\$ _____
1.2	2-#1/0+Gnd Teck 90 Armored Cable, requires 3 conductors		M	375	\$ _____	\$ _____
1.3	2-#2/0+Gnd Teck 90 Armored Cable, requires 3 conductors		M	202	\$ _____	\$ _____
1.4	3-#6+Gnd Teck 90 Armored Cable		M	100	\$ _____	\$ _____
1.5	3-#3+Gnd Teck 90 Armored Cable		M	86	\$ _____	\$ _____
1.6	3-#1+Gnd Teck 90 Armored Cable		M	275	\$ _____	\$ _____
1.7	3-#1/0+Gnd Teck 90 Armored Cable		M	592	\$ _____	\$ _____
1.8	3-#2/0+Gnd Teck 90 Armored Cable		M	333	\$ _____	\$ _____
1.9	103mm Schedule 40 PVC Conduit		M	50	\$ _____	\$ _____
1.10	2 pole, 240V, 50A Circuit Breaker, Eaton, bolt-on.		Each	16	\$ _____	\$ _____
1.11	2 pole, 240V, 30A Circuit Breaker, Eaton, bolt-on.		Each	1	\$ _____	\$ _____
1.12	1 pole, 120V, 50A Circuit Breaker, Eaton, bolt-on.		Each	2	\$ _____	\$ _____

1.13	36" x 24" x 8" Type 1 Enclosure from 16 gauge steel with bolted cover and ground connection. Separate lugs: 18 pcs - open power distribution blocks, wire range 2/0-#14, three pole one opening per pole. 185 amp CSA rated. Dimensions: Height=75 mm, Width=45 mm, Depth=50 mm.		Each	3	\$ _____	\$ _____
1.14a	#6AWG RW90 Wiring, white		M	50	\$ _____	\$ _____
1.14b	#6AWG RW90 Wiring, black		M	50	\$ _____	\$ _____
	Total Aggregate Price for <u>Power Feed Materials</u>					\$ _____

2. Campsite Power Posts Materials

Item No.	Description	OEM Brand Name and Model Number	Unit of issue	Quantity	Unit Price	Extended price
2.1	Recreational vehicle load centres, c/w 1-30 amp 125v and 1-20 amp 125v receptacle Provide electrical power to individual recreational vehicle park sites. Each receptacle protected by appropriate circuit breaker. 10,000 RMS Symmetrical Ampere short circuit current rating. All receptacles and circuit breakers included. Lugs to loop through neutral 2/0 - #6. Load centres must have both breakers on a common busbar.		Each	34	\$ _____	\$ _____

2.2	<p>Junction boxes, CSA type c/w tamper proof screws. 3R painted steel galvanized. Width=8", Height=12", Depth=4". Formed and spot-welded from 16 or 14 gauge galvanized steel. Drip-shield top and seam-free sides, front and back. Slip-on removable cover fastened with plated steel screws. Door handles on body type C enclosures. Embossed mounting holes on back of enclosure. Easily removed knockouts on bottom of enclosure. Separate lugs: 34 pcs - open power distribution blocks, wire range 2/0-#14 two pole one opening per pole. 185 amp CSA rated. Dimensions: Height=75 mm, Width=45 mm, Depth=50 mm.</p> <p>16 pcs - open power distribution blocks, wire range 2/0-#14 single primary two poles secondary. 185 amp CSA rated. Dimensions: Height=75 mm, Width=45 mm, Depth=50 mm.</p>		Each	34	\$ _____	\$ _____
2.3	PVC Cable Guard, 78mm Wide, 3m Long		Each	17	\$ _____	\$ _____
2.4	27mm Schedule 40 PVC Conduit		M	11	\$ _____	\$ _____
2.5a	#6AWG RW90 Wiring, white		M	25	\$ _____	\$ _____

Solicitation No. - N° de l'invitation
5P131-151008/A
Client Ref. No. - N° de réf. du client
5P131-151008

Amd. No. - N° de la modif.
001
File No. - N° du dossier
MCT-5-38122

Buyer ID - Id de l'acheteur
mct011
CCC No./N° CCC - FMS No./N° VME

2.5b	#6AWG RW90 Wiring, black		M	25	\$ _____	\$ _____
	Total Aggregate Price for <u>Campsite Power Posts</u> <u>Materials</u>					\$ _____