



## AMENDMENT #1:

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS  
À:**  
Parks Canada Agency  
National Contracting Services  
Bid Receiving Unit  
111, Water Street East  
Cornwall ON K6H 6S3

**Tender To: Parks Canada Agency**  
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**  
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency  
111, Water Street East  
Cornwall ON K6H 6S3

<b>Title-Sujet</b> Rehabilitation to Broad Cove Bridge (aka the Eastport Road Causeway Bridge) in Terra Nova National Park, NL		
<b>Solicitation No. - No. de l'invitation</b> 5P300-16-5018/A		<b>Date:</b> April 15, 2016
<b>GETS Reference No. – No de reference de SEAG</b> PW-16-00728356		<b>Client Ref. No. – No. de réf du client.</b> 675
<b>Solicitation Closes:</b>		
<b>at – à</b> 02:00 PM	<b>on – le</b> April 19, 2016	<b>Time Zone - Fuseau horaire</b> EDT - HAE
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Patrick Alguire – <a href="mailto:patrick.alguire@pc.gc.ca">patrick.alguire@pc.gc.ca</a>		
<b>Telephone No. - No de téléphone</b> (613) 938-5955		<b>Fax No. – No de FAX:</b>
<b>Destination of Goods, Services, and Construction: Destinations des biens, services et construction:</b>		
See Herein – Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)  
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)**

<b>Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de téléphone:</b> _____	
<b>Facsimile No. - N° de télécopieur:</b> _____	
<b>Email - Courriel:</b> _____	
<b>Signature</b>	<b>Date</b>

---

**THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.**

**The following changes have been made to the DSP**

**In:** DSP 1.zip, 2 Drawings, 15218-S12.pdf

**Section, Part:** LIST OF APPROVED EXPANSION JOINTS.

**Add:**

3. DS Brown's Box Seal Edge Beam Extrusions & MA4001 Seal.

**In:** DSP 1.zip, 2 Drawings, 15218-S11.pdf

**Section, Part:** MATERIAL NOTES

**Delete:**

10. STRUCTURAL TUBING SHALL CONFORM TO THE REQUIREMENTS OF ASTM A1085

**Replace With:**

10. STRUCTURAL TUBING SHALL CONFORM TO THE REQUIREMENTS OF ASTM A1085 OR CAN CSA G40.21 GRADE 350W CLASS C.

**Questions and Answers:**

Q1) For the structural steel plate girder assemblies – what qualifications are required for the fabricator/shop? Specifically – is it a requirement for the fabricator (fabrication shop) to have CISC Certification?

A1) The specifications do not specify that the fabrication shop be registered with CISC. However, all steel fabrication has to be done in accordance with CSA S6, and CSA W59.

By submission of its tender, the tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

**All other terms & conditions remain unchanged.**