

Solicitation No. - N° de l'invitation
EQ754-162752/A

Client Ref. No. - N° de réf. du client
VME
R.074850.001

Amd. No. - N° de la modif.
002

File No. - N° du dossier
PWL-5-38221

Buyer ID - Id de l'acheteur
pwl012

CCC No./N° CCC - FMS No/ N°

Question and Answer

Attachment No. 005

Q1. On Drawing C-300 Pavement Make-Up & Lap Joint Detail it shows 2 sets of different measurements for the same area. It asks for 65mm of HL4 in the drawing and 50mm of HL4 in the note directly beside. It also asks for 200mm of granular 'A' in the drawing and 150 mm of Granular 'A' in the note. Can you please clarify which measurements are correct?

A1. The Pavement Structure shall be the following:

- 65mm HL4 Surface Asphalt
- 50mm HL8 Base Asphalt
- 200 Granular 'A'
- 450 Granular 'B'