



AMENDMENT #2:

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS
À:**

**Parks Canada Agency
National Contracting Services
Bid Receiving Unit
111, Water Street East
Cornwall ON K6H 6S3**

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Issuing Office - Bureau de distribution

**Parks Canada Agency
111, Water Street East
Cornwall ON K6H 6S3**

Title-Sujet Bridge replacement - Southeast Brook Bridge, Gros Morne National Park, Newfoundland		
Solicitation No. - No. de l'invitation 5P300-16-5025/A		Date: April 28, 2016
GETS Reference No. - No de reference de SEAG PW-16-00729538		Client Ref. No. - No. de réf du client. 414
Solicitation Closes:		
at - à 02:00 PM	on - le May 03, 2016	Time Zone - Fuseau horaire EDT - HAE
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Patrick Alguire – patrick.alguire@pc.gc.ca		
Telephone No. - No de téléphone (613) 938-5955		Fax No. - No de FAX:
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein – Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)**

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Email - Courriel: _____	
Signature	Date

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

1. Revision to the Specifications and revised Drawings

DSP 4.zip contains the following:

1. Revisions to the specifications document, see "addendum 1 (april 27-16).pdf"
2. Revised drawings showing existing sign locations and details see "C-1 –R1.pdf" and "C-3 –R1.pdf"

2. Questions and Answers:

Q5) It states that the new replacement bridge shall be open to traffic prior to the October 1, 2016, Is this time frame correct?

A5) Please see attached addendum. Bridge construction by November 30, 2016, Final completion date June 30th.

Q6) Lump Sum Item 2 - Special Procedures for traffic control states "signage and barricades for closure of rest area and picnic area". What are the locations of the rest area that will be closed?

A6) Clause revised. See "addendum 1 (april 27-16).pdf" in "DSP 4.zip"

Q7) Lump Sum Item 4 - Selective Site Demolition states "The removal, transporting and disposal of existing driveway culverts". Where are these culverts located?

A7) Clause removed. See "addendum 1 (april 27-16).pdf" in "DSP 4.zip"

Q8) Lump Sum Item 5 - Concrete Reinforcing GFRP. Is there quantity for tonnage that should be attached to this unit?

A8) Lengths are depicted and quantified within reinforcement bar schedules within the structural drawings.

Q9) Lump Sum Item 6-Temporary Modular bridge, Will this bridge remain property of Parks Canada after it is removed from the site?

A9) Components shall not become property of PCA. See "addendum 1 (april 27-16).pdf" in "DSP 4.zip"

Q10) Lump Sum Item 7-Pavement Marking. Is there a drawing that shows what marking is required and how long of a stretch of highway is affected?

A10) Match existing within limits of contract. Pavement markings are solid yellow and to be from contract limit to contract limit.

Q11) Unit Item 3-Precast Structural Concrete Beams NEBT 1800, Could post tension girders be manufactured on site?

A11) No, this would be a design change.

Q12) Unit Item 7- Traffic Signage. Is there a drawing showing what size of signs, material required for each and location where each sign is required?

A12) Signs and details to be shown on plans (1 Regulatory and 2 Parks signs). Drawing should be revised and re-issued to show existing sign locations and details. (See "DSP 4.zip")

Q13) Will the excess material removed from the North side to accommodate the diversion be allowed to be used in the South side of the diversion?

A13) If excavated material meets specifications and is approved by Departmental Rep, it can be used.

- Q14) The drawings don't show a concrete footing on the abutment walls. Is this correct or is this an oversight
A14) Drawings are correct - integral abutment bridge.
- Q15) Is an AASHTO 6 girder a suitable alternative for the NEBT 1800 girder shown on tender documents?
A15) No, this would be a design change.
- Q16) A landscaping subcontractor advises that the mulch specified is unsuitable for blown mulch. Please clarify.
A16) Mulch has been used in previous tenders. Contractor may have to look for alternative sub-contractor.
- Q17) We have been unable to locate a subcontractor that has a tar pot with an agitator, as required by the spec for the deck waterproofing. Would a torch-down waterproofing be acceptable? It has been acceptable for other Parks Canada projects. Please advise.
A17) Contractor must submit an alternative product for review. Contractor must bid as specified.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.