

---

**Washroom Buildings Recapitalization  
Buildings 32, 34 & 38  
Newman Sound Campground  
Terra Nova National Park, NL  
Proj. No.: R.079272.001**

Section 26 05 34 – Conduits, Conduit Fastenings and Conduit Fittings

Page 1 of 4

---

**PART 1**      **GENERAL**

**1.1**            **REFERENCES**

- .1 Canadian Standards Association (CSA)
  - .1 CAN/CSA C22.2 No. 18, Outlet Boxes, Conduit Boxes, and Fittings and Associated Hardware, a National Standard of Canada.
  - .2 CSA C22.2 No. 45, Rigid Metal Conduit.
  - .3 CSA C22.2 No. 56, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
  - .4 CSA C22.2 No. 83, Electrical Metallic Tubing.
  - .5 CSA C22.2 No. 211.2, Rigid PVC (Unplasticized) Conduit.

**1.2**            **SUBMITTALS**

- .1 Product data: submit manufacturer's printed product literature, specifications and datasheets.
  - .1 Submit cable manufacturing data.
- .2 Quality assurance submittals:
  - .1 Test reports: submit certified test reports.
  - .2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
  - .3 Instructions: submit manufacturer's installation instructions.

**PART 2**      **PRODUCTS**

**2.1**            **CONDUITS**

- .1 Rigid metal conduit: to CSA C22.2 No. 45, hot dipped galvanized steel threaded.
- .2 Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings.
- .3 Rigid PVC conduit: to CSA C22.2 No. 211.2.
- .4 Flexible metal conduit: to CSA C22.2 No. 56, aluminum liquid-tight flexible metal.

**2.2**            **CONDUIT FASTENINGS**

- .1 One hole steel straps to secure surface conduits 50 mm and smaller. Two hole steel straps for conduits larger than 50 mm.

---

**Washroom Buildings Recapitalization  
Buildings 32, 34 & 38  
Newman Sound Campground  
Terra Nova National Park, NL  
Proj. No.: R.079272.001**

Section 26 05 34 – Conduits, Conduit Fastenings and Conduit Fittings

Page 2 of 4

---

- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Channel type supports for two or more conduits at 1.5 m oc.
- .4 Threaded rods, 6 mm dia., to support suspended channels.

**2.3 CONDUIT FITTINGS**

- .1 Fittings: manufactured for use with conduit specified. Coating: same as conduit.
- .2 Factory "ells" where 90°, 45° or 22.5° bends are required for 25 mm and larger conduits.
- .3 Ensure conduit bends other than factory "ells" are made with an approved bender. Making offsets and other bends by cutting and rejoining 90 degree bends are not permitted.
- .4 Connectors and couplings for EMT. Steel set-screw type, size as required.

**2.4 EXPANSION FITTINGS FOR RIGID CONDUIT**

- .1 Weatherproof expansion fittings with internal bonding assembly suitable for 100 mm linear expansion.
- .2 Watertight expansion fittings with integral bonding jumper suitable for linear expansion and 19 mm deflection in all directions.
- .3 Weatherproof expansion fittings for linear expansion at entry to panel.

**2.5 FISH CORD**

- .1 Polypropylene.

**PART 3 EXECUTION**

**3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

**3.2 INSTALLATION**

- .1 Install all conduit, conduit fittings and accessories in accordance with the latest edition of the Canadian Electrical Code in a manner that does not alter, change or violate any

---

**Washroom Buildings Recapitalization**  
**Buildings 32, 34 & 38**  
**Newman Sound Campground**  
**Terra Nova National Park, NL**  
**Proj. No.: R.079272.001**

Section 26 05 34 – Conduits, Conduit Fastenings and Conduit Fittings

Page 3 of 4

---

part of the installed system components or the CSA/UL certification of these components.

- .2 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .3 Conceal all conduits except in mechanical and electrical service rooms and in unfinished areas.
- .4 Surface mount conduits except in finished areas or as indicated.
- .5 Use rigid hot dipped galvanized steel threaded conduit for exposed work below 2.4 m above finished floor.
- .6 Use electrical metallic tubing (EMT) except in cast concrete and above 2.4 m not subject to mechanical injury, as well as concealed work in masonry construction.
- .7 Use rigid PVC conduit underground and buried in or under concrete slab on grade.
- .8 Use flexible metal conduit for connection to motors in dry areas, connection to recessed light fixtures without a prewired outlet box, connection to surface or recessed light fixtures and work in movable metal partitions.
- .9 Use liquid tight flexible metal conduit for connection to motors or vibrating equipment in damp, wet or corrosive locations.
- .10 Use AC-90 for vertical power supply drops to light fixtures.
- .11 Install conduit sealing fittings in hazardous areas. Fill with compound.
- .12 Minimum conduit size for lighting and power circuits: 21 mm.
- .13 Bend conduit cold. Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .14 Mechanically bend steel conduit over 21 mm dia.
- .15 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .16 Install fish cord in empty conduits.
- .17 Run 2 - 27 mm spare conduits up to ceiling space from each flush panel. Terminate these conduits in 152 x 152 x 102 mm junction boxes in ceiling space or in case of an exposed concrete slab, terminate each conduit in flush concrete type box.
- .18 Remove and replace blocked conduit sections. Do not use liquids to clean out conduits.

---

**Washroom Buildings Recapitalization  
Buildings 32, 34 & 38  
Newman Sound Campground  
Terra Nova National Park, NL  
Proj. No.: R.079272.001**

Section 26 05 34 – Conduits, Conduit Fastenings and Conduit Fittings

Page 4 of 4

---

- .19 Dry conduits out before installing wire.

**3.3 SURFACE CONDUITS**

- .1 Run parallel or perpendicular to building lines.
- .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
- .3 Run conduits in flanged portion of structural steel.
- .4 Group conduits wherever possible on suspended channels.
- .5 Do not pass conduits through structural members except as indicated.
- .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.

**3.4 CONCEALED CONDUITS**

- .1 Run parallel or perpendicular to building lines.
- .2 Do not install horizontal runs in masonry walls.
- .3 Do not install conduits in terrazzo or concrete toppings.

**3.5 CONDUITS UNDERGROUND**

- .1 Slope conduits to provide drainage.
- .2 Waterproof joints (PVC excepted) with heavy coat of bituminous paint.

**3.6 CLEANING**

- .1 Proceed in accordance with Section 01 74 00 – Cleaning and Waste Management.
- .2 On Completion and verification of performance of installation, remove surplus materials, excess materials rubbish, tools and equipment.