


PLUMBING FIXTURE AND TRIM SCHEDULE																					
FIXTURE TAG	MANUF.	MODEL NO.	COLOUR	WATER CLOSET & URINAL TRIM				SINK & LAVATORY TRIM					SHOWER & BATH TRIM			MOUNTING	ROUGHING				REMARKS
				SUPPLY/VALVE	TANK	CARRIER	SEAT	FAUCET	WASTE	TRAP	SUPPLIES	CARRIER	HEAD	FAUCET OR MIXING VALVE	WASTE & OVERFLOW		WASTE	VENT	HOT WATER	COLD WATER	
WC-1	AMERICAN STANDARD	CHAMPION 4 2034.314	WHITE	DELTA 47P1316SD	-	-	BEMIS 2L2150T	-	-	-	-	-	-	-	FLOOR MTD.	75mm	50mm	-	12mm	BARRIER FREE, ELONGATED 419mm HIGH BOWL.	
WC-2	AMERICAN STANDARD	CHAMPION 4 2004.314	WHITE	DELTA 47P1316SD	-	-	BEMIS 2L2150T	-	-	-	-	-	-	-	FLOOR MTD.	75mm	50mm	-	12mm	ELONGATED 381mm HIGH BOWL.	
UR-1	AMERICAN STANDARD	WASHBROOK 6590.005	WHITE	DELTA 81T231HWA	-	ZURN Z-1223	-	-	-	-	-	-	-	-	WALL MTD.	50mm	40mm	-	40mm	C/W STAINLESS STEEL STRAINER AND SUITABLE REINFORCEMENT FOR WALL SUPPORTS. C/W DELTA # 1600T6403RI ROUGH IN.	
LAV-1	AMERICAN STANDARD	OVALYN 9482.000	WHITE	-	-	-	-	DELTA 22C301	DELTA 33T290	DELTA 33T311	DELTA 47T2512SD	-	-	-	WALL MTD.	32mm	40mm	12mm	12mm	HARDWIRED, C/W ENCLOSED BOTTOM, STAINLESS STEEL SPOUT, MIXING VALVE AND WALL SUPPORT.	
SH-1	-	-	-	-	-	-	-	-	-	-	-	-	DELTA T13H163-25	-	-	50mm	40mm	12mm	12mm	C/W DELTA R10000-UNIS ROUGH IN. AND PISTON ACTUATED METERING SHOWER VALVE. SHOWER OFF AFTER 45 SECONDS FULL FLOW, FOR TEMPERED WATER, CONCEALED METERING VALVE WITH INTEGRAL STOP, NPS 1/2 SWEAT CONNECTIONS, VANDAL RESISTANT RECESSED FASTENERS, CAST BRASS INSTITUTIONAL WALL MOUNTED SHOWER HEAD, POLISHED CHROME PLATED FINISH, 7.5 L/min FLOW CONTROL, FIXED SPRAY, CONCEALED CAST BRASS MOUNTING PLATE, VANDAL RESISTANT FRONT MOUNTING SCREWS, UNIVERSAL NPS 1/2 FIP/COOPER SWEAT INLET, NPS 3/4 SPRAY ANGLE, ACCEPTABLE PRODUCT COMPLIANCE, ZURN 77116-SS-12.	
SH-2	-	-	-	-	-	-	-	-	-	-	-	-	DELTA T13H163	-	-	50mm	40mm	12mm	12mm		
TP	PPP INC.	P1-500	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	12mm	C/W DISTRIBUTION UNIT WITH 2-4 OUTLETS AS REQ'D BY NUMBER OF TRAPS SERVED. NCI REQ'D FOR ONLY ONE TRAP.	
SK-1	KINDRED	LBD7508-1	S.S.	-	-	-	-	DELTA 26C3954	CRUMB CUP STRAINER	DELTA 33T360	DELTA 47T2512SD	-	-	-	COUNTER MTD.	50mm	40mm	12mm	12mm	C/W 89mm CRUMB CUP STRAINER, LEDGE BACK DRILLED FOR 203mm O.C. DECK FAUCET.	
HWT-1	65 GALLON PROPANE HOT WATER TANK (322 Litres) MODEL TO BE RHEEM-RUUD R71-360C(A)																				

FLOOR DRAIN SCHEDULE									
TAG NO.	MODEL NO.	MANUF.	GRATING FLASHING	CLAMP	TRAP	TRAP SEAL PRIMER	SPECIAL REQUIREMENTS	AREA OF APPLICATION	REMARKS
FD-1	ZN-415-B-P	ZURN	YES	YES	REQ'D	REQ'D	—	SEE DRAWING	OUTLET SIZE AS PER DRAWING.
FD-2	ZN-415-B	ZURN	YES	YES	REQ'D	NO	—	SEE DRAWING	OUTLET SIZE AS PER DRAWING.

FAN SCHEDULE															
					FAN DATA						MOTOR DATA				
					AIR FLOW (L/s)	STATIC (Pa.)	FAN SPEED RPM	SONES @ 0 Pa	OPERATION KW (BHP)	WATTS	ELECTRICAL DATA				
TAG NO.	SYSTEM SERVICED	MANUF.	MODEL NO.	TYPE							VOLTAGE	PH.	HZ.	MOUNTING	REMARKS
F-1	WASHROOMS	GREENHECK	SP-A390	EXHAUST	153	124	1350	—	—	135	120	1	60	CEILING MOUNTED	C/W ELECTRICAL PLUG IN, BIRDSCREEN & WALLCAP. WALL CAP COLOR TO MATCH BUILDING.

Stamp



Permit

PROVINCE OF NEWFOUNDLAND
PERMIT HOLDER
Class "A"
This Permit Allows:
CROSSER ENGINEERING LIMITED

To practice Professional Engineering
in Newfoundland and Labrador
Permit No. as issued by PEGG-NL 00123
which is valid for the year 2016.

2.	ISSUED FOR TENDER	2016/03/04
1.	ISSUED FOR TENDER REVIEW	2015/09/11
revisions		date

project

project

WASHROOM BUILDING
RECAPITALIZATION
BUILDING 32, 34, & 38
NEWMAN SOUND CAMPGROUND
TERRA NOVA
NATIONAL PARK, NL

drawing

dessin

FLOOR PLAN BUILDING
#32, #34, & #38 -
PLUMBING & VENTILATION
SCHEDULES

designed

conçu

date

dessiné

drawn

date

approved

approuvé

date

Tender

Signature

22 April 2016

Soumission

PWOSC Project Manager

Administrateur de projets TPSCC

project number

no. du projet

R-079272-001

drawing no.

no. du dessin

M-3

PWOSC A1 (2004)

E-DRM/GDD-E: 185267