
**Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001**

Section 26 28 23 – Disconnect Switches – Fused and Non-Fused

Page 1 of 1

PART 1 **GENERAL**

1.1 **RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 26 05 00 – Common Work Results - Electrical.

PART 2 **PRODUCTS**

2.1 **DISCONNECT SWITCHES**

- .1 Fusible and non-fusible, disconnect switch in CSA Enclosure type 1, size as indicated.
- .2 Provision for padlocking in on-off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Fuses: size as indicated, to Section 26 28 13.01 - Fuses - Low Voltage.
- .5 Fuseholders: suitable without adaptors, for type and size of fuse indicated.
- .6 Quick-make, quick-break action.
- .7 ON-OFF switch position indication on switch enclosure cover.
- .8 EEMAC 1 for interior and EMMAC 4X for exterior use.
- .9 All disconnects to be heavy duty rated.

2.2 **EQUIPMENT IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

PART 3 **EXECUTION**

3.1 **INSTALLATION**

- .1 Install disconnect switches complete with fuses as indicated.