
Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001
Section 26 29 01 – Contactors

Page 1 of 2

PART 1 **GENERAL**

1.1 **SECTION INCLUDES**

- .1 Materials and installation for contactors for system voltages up to 600 V

1.2 **RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 26 05 00 – Common Work Results - Electrical.
- .3 Section 26 29 03 - Control Devices.

1.3 **REFERENCES**

- .1 Canadian Standards Association (CSA)
 - .1 CSA C22.2 No.14, Industrial Control Equipment.

PART 2 **PRODUCTS**

2.1 **CONTACTORS**

- .1 Contactors: to CSA C22.2 No.14.
- .2 Electrically held controlled by pilot devices as indicated and rated for type of load controlled. Half size contactors not accepted.
- .3 Fused switch combination contactor as indicated.
- .4 Complete with 2 normally open and 2 normally closed auxiliary contacts unless indicated otherwise.
- .5 Mount in CSA Enclosure 1 unless otherwise indicated.
- .6 Include following options in cover:
 - .1 Red indicating lamp.
 - .2 Hand-Off-Auto selector switch.
- .7 Control transformer: in accordance with Section 26 29 03 - Control Devices, in contactor enclosure.

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001
Section 26 29 01 – Contactors

Page 2 of 2

2.2 **EQUIPMENT IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.

- .2 Size 4 nameplate indicating name of load controlled as indicated.

PART 3 **EXECUTION**

3.1 **INSTALLATION**

- .1 Install contactors and connect auxiliary control devices.

END OF SECTION