
**Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001**

Section 22 42 01 – Plumbing Specialties and Accessories

Page 1 of 10

PART 1 GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Materials and installation for plumbing specialties and accessories.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 – Submittal Procedures.
- .2 Section 01 35 28 – Health and Safety Requirements.
- .3 Section 01 45 00 – Quality Control.
- .4 Section 01 78 00 – Closeout Submittals.

1.3 REFERENCES

- .1 American Society for Testing and Materials International (ASTM)
 - .1 ASTM A126, Specification for Gray Iron Castings for Valves, Flanges and Pipe Fittings.
 - .2 ASTM B62, Specification for Composition Bronze or Ounce Metal Castings.
- .2 American Water Works Association (AWWA)
 - .1 AWWA C700, Cold Water Meters-Displacement Type, Bronze Main Case.
 - .2 AWWA C701, Cold Water Meters-Turbine Type for Customer Service.
 - .3 AWWA C702, Cold Water Meters-Compound Type.
- .3 American National Standards Institute (ANSI)
 - .1 ANSI Z358.1 Emergency eyewash and shower equipment.
- .4 Canadian Standards Association (CSA)
 - .1 CSA-B64 Series, Backflow Preventers and Vacuum Breakers.
 - .2 CSA-B356, Water Pressure Reducing Valves for Domestic Water Supply Systems.
- .5 Health Canada/Workplace Hazardous Materials Information Systems (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .6 Plumbing and Drainage Institute (PDI)
 - .1 PDI-G101, Testing and Rating Procedure for Grease Interceptors with Appendix of Sizing and Installation Data.
 - .2 PDI-WH201, Water Hammer Arresters Standard.

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001

Section 22 42 01 – Plumbing Specialties and Accessories

Page 2 of 10

1.4 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet for fixtures and equipment.
 - .2 Indicate dimensions, construction details and materials for specified items.
 - .3 Submit WHMIS MSDS in accordance with Section 02 62 00.01 – Hazardous Materials. Indicate VOC's for adhesive and solvents during application and curing.
- .3 Shop Drawings:
 - .1 Submit shop drawings to indicate materials, finishes, method of anchorage, number of anchors, dimensions, construction and assembly details and accessories.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Closeout submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 – Closeout Submittals. Include:
 - .1 Description of plumbing specialties and accessories, giving manufacturer's name, type, model, year and capacity.
 - .2 Details of operation, servicing and maintenance.
 - .3 Recommended spare parts list.

1.5 QUALITY ASSURANCE

- .1 Pre-Installation Meetings:
 - .1 Convene pre-installation meeting one week prior to beginning work of this Section and on-site installations.
 - .1 Verify project requirements.
 - .2 Review installation and substrate conditions.
 - .3 Co-ordination with other building subtrades.
 - .4 Review manufacturer's installation instructions and warranty requirements.
 - .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 28 – Health and Safety Requirements.

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001

Section 22 42 01 – Plumbing Specialties and Accessories

Page 3 of 10

1.6 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Division 01.
 - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
 - .3 Collect and separate for disposal, paper, plastic, polystyrene, corrugated cardboard packaging materials in appropriate on-site bins for recycling in accordance with Waste Management Plan.
 - .4 Divert unused metal materials from landfill to metal recycling facility as approved by Owner’s Representative.
 - .5 Fold up metal and plastic banding flatten and place in designated area for recycling.

PART 2 PRODUCTS

2.1 FLOOR DRAINS

- .1 Floor drains and trench drains.
 - .1 Provide floor drains in accordance with “floor drain schedule” shown on drawings.

2.2 CLEANOUTS

- .1 Cleanout plugs: heavy cast iron male ferrule with brass screws and threaded brass or bronze plug. Sealing-caulked lead seat or neoprene gasket.
 - .1 Acceptable Product: Zurn, Jay R. Smith, MIFAB.
- .2 Access covers:
 - .1 Wall access: face or wall type, or stainless steel square cover with flush head securing screws, bevelled edge frame complete with anchoring lugs.
 - .2 Floor access: round cast iron body and frame with adjustable secured nickel bronze top.
 - .1 Plugs: bronze with neoprene gasket.
 - .2 Cover for unfinished concrete floors: cast iron round, gasket, vandal-proof screws.
 - .3 Cover for tile and linoleum floors: polished nickel bronze with recessed cover for linoleum or tile infill, complete with vandal-proof locking screws.

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001

Section 22 42 01 – Plumbing Specialties and Accessories

Page 4 of 10

- .4 Cover for carpeted floors: polished nickel bronze with deep flange cover for carpet infill, complete with carpet retainer vandal-proof locking screws.

2.3 WATER HAMMER ARRESTORS

- .1 Stainless steel or copper construction, bellows or piston type: to PDI-WH201.
- .2 Acceptable Product: Zurn, Jay R. Smith, MIFAB, Precision Plumbing Products.

2.4 BACK FLOW PREVENTERS

- .1 To CSA-B64 Series.
- .2 Application: domestic service entrance and fire protection system service entrance.
 - .1 Domestic water:
 - .1 Reduced pressure principle type consisting of a pressure differential relief valve located between two independently operated spring-loaded centre guided check valves.
 - .2 Ductile iron construction with FDA approved fusion epoxy coat inside and out.
 - .3 Compound check.
 - .4 Single access cover.
 - .5 Maximum temperature range: 0.5°C to 60°C.
 - .6 Maximum pressure: 1205 kPa.
 - .7 CSA certified.
 - .8 Acceptable Product: Wilkins Model 375L, Watts, Zurn.
 - .2 Fire protection water:
 - .1 Same as above except without compound check and with FM and ULC approval for fire protection service.
 - .2 Acceptable Product: Wilkins Model 975L, Watts, Zurn.
- .3 Application: install on domestic cold water supply to electrode steam humidifier.
 - .1 Bronze body construction.
 - .2 Internal pressure differential relief valve located in a zone between two positive seating check modules with captured springs and silicone seat discs.
 - .3 Seats and discs replaceable in both check modules and the relief valve.
 - .4 Assembly to include two resilient seated isolation valves, four resilient seated test cocks, protective wye strainer with 20 mesh screen, union end connections and an air gap drain fitting.

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001

Section 22 42 01 – Plumbing Specialties and Accessories

Page 5 of 10

- .5 Reduced pressure zone type backflow preventer.
- .6 Acceptable Product: Watts Series U-009QT-S complete with Watts Series 909AG air gap, Wilkins, Zurn.
- .4 Provide backflow preventer test kit as follows:
 - .1 Maximum working pressure: 1205 kPa.
 - .2 Maximum working temperature: 98.8°C.
 - .3 0-103 kPa and 0-15 psig dual scale pressure gauge with 114 mm diameter face, ±2% accuracy.
 - .4 Test valves: two (2) ball valves and one (1) needle valve.
 - .5 Hoses: three (3) one (1) metre test hoses with female threaded swivel coupling.
 - .6 Adapters:
 - .1 Three (3) NPS ¼ threaded coupling adapters.
 - .2 Three (3) NPS ½ x NPS ¼ bushings.
 - .3 Three (3) NPS ¾ x NPS ¼ bushings.
 - .7 400 mm long securing strap.
 - .8 Moisture resistant instruction guide.
 - .9 Light weight, shock resistant molded plastic case with foam inserts.
 - .10 Acceptable Product: Watts No. TK-9A Backflow Preventer Test Kit, Precisions Plumbing Products, MIFAB.

2.5 VACUUM BREAKERS

- .1 To CSA-B64 Series.
- .2 Atmospheric vacuum breaker (inlet to domestic hot water tanks):
 - .1 Plain brass body with silicone disc.
 - .2 Suitable for temperatures up to 82°C.
 - .3 Maximum operating pressure: 860 kPa.
 - .4 Size: NPS ¾.
 - .5 Acceptable Product: Watts Series 288a, Wilkins, Jay R. Smith, MIFAB.
- .3 Hose connection vacuum breaker:
 - .1 NPS ¾ female hose thread inlet, NPS ¾ male hose thread outlet, brass finish.

2.6 HOSE BIBBS AND SEDIMENT FAUCETS

- .1 Bronze construction complete with integral back flow preventer, hose thread spout, replaceable composition disc, and chrome plated in finished areas.

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001

Section 22 42 01 – Plumbing Specialties and Accessories

Page 6 of 10

2.7 TRAP SEAL PRIMERS

- .1 Pressure drop actuated:
 - .1 Brass body construction with inlet opening of ½ male NPT and outlet opening of female ½ NPT.
 - .2 Provide complete with four-hole view built-in air gap to prevent any backflow from trap being fed into the water supply.
 - .3 Provide removable inlet filter screen.
 - .4 Capacity to serve up to four (4) floor drains.
 - .5 Provide complete with trap seal primer distribution unit as follows:
 - .1 Brass body construction.
 - .2 ½ NPT inlet connection.
 - .3 Four (4) 3/8 FPT brass nipple outlet connections.
 - .4 Four (4) 6 mm diameter vent holes in lid to provide air gap and backflow protection.
 - .6 Acceptable Product: MIFAB MR-500 trap seal primer complete with MIFAB MI-DU series distribution unit, Precision Plumbing Products, Zurn.
- .2 Up to 12 floor drains: Electronic trap priming manifold with:
 - .1 Vacuum breaker
 - .2 Pre-set 24 hour time clock
 - .3 Manual override switch
 - .4 120V solenoid valve
 - .5 120V or 3 wire connection.
 - .6 NPS ¾ inlet connection.
 - .7 Calibrated manifold.
 - .8 Water hammer arrestor
 - .9 Mounted in steel cabinet
 - .10 Compression outlet fittings
 - .11 Inlet shut off valve
 - .12 Supplies minimum 59 ml @ 138 kPa.

2.8 STRAINERS

- .1 860 kPa, Y type with 20 mesh, monel, bronze or stainless steel removable screen.
- .2 NPS2 and under, bronze body, screwed ends, with brass cap, tapped blowoff and plug.
- .3 NPS2½ and over, cast iron body, flanged ends, with bolted cap, tapped blow off connection with bronze ball valve.

**Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001**

Section 22 42 01 – Plumbing Specialties and Accessories

Page 7 of 10

2.9 PIPE WALL AND FLOOR PENETRATION SEAL

- .1 Application:
 - .1 Pipes penetrating exterior concrete walls below grade and concrete floors on grade.
- .2 Seal material to be EPDM.
- .3 Pressure plates to be glass-reinforced plastic.
- .4 Bolts and nuts to be stainless steel 18-8.
- .5 Suitable temperature range to be -40°C to 121°C.
- .6 Wall sleeves to be Schedule 40 black iron pipe. Sleeves in exterior walls to be galvanized.
- .7 Acceptable Product: Metraseal MS Series, Link Seal.

PART 3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: Comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.

3.2 INSTALLATION

- .1 Install in accordance with Canadian Plumbing Code, and local authority having jurisdiction.
- .2 Install in accordance with manufacturer's instructions and as specified.

3.3 CLEANOUTS

- .1 In addition to those required by code, and as indicated, install at base of soil and waste stacks, and rainwater leaders.
- .2 Bring cleanouts to wall or finished floor unless serviceable from below floor.
- .3 Building drain cleanout and stack base cleanouts: line size to maximum NPS4.

3.4 WATER HAMMER ARRESTORS

- .1 Install on branch supplies to fixtures or group of fixtures where indicated.

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001

Section 22 42 01 – Plumbing Specialties and Accessories

Page 8 of 10

3.5 BACK FLOW PREVENTORS

- .1 Install in accordance with CSA-B64 Series, where indicated and elsewhere as required by code.
 - .1 Reduced pressure type where backflow would constitute a health hazard.
 - .2 Double check type where backflow would constitute a nuisance or be aesthetically objectionable or material which would not constitute a health hazard.
- .2 Pipe discharge to terminate over nearest drain and or service sink.

3.6 HOSE BIBBS AND SEDIMENT FAUCETS

- .1 Install at bottom of risers, at low points to drain systems, and as indicated.

3.7 TRAP SEAL PRIMERS

- .1 Install for floor drains and elsewhere, as indicated.
- .2 Install on cold water supply to nearest frequently used plumbing fixture, in concealed space, to approval of Owner's Representative.
- .3 Install Type K soft copper tubing to floor drain.

3.8 STRAINERS

- .1 Install with sufficient room to remove basket.

3.9 START-UP AND COMMISSIONING

- .1 General:
 - .1 In accordance with Division 01.
- .2 Timing: Start-up only after:
 - .1 Pressure tests have been completed.
 - .2 Disinfection procedures have been completed.
 - .3 Water treatment systems operational.
- .3 Provide continuous supervision during start-up.

3.10 TESTING AND ADJUSTING

- .1 General:
 - .1 In accordance with Division 01.

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001

Section 22 42 01 – Plumbing Specialties and Accessories

Page 9 of 10

- .2 Timing:
 - .1 After start-up deficiencies rectified.
 - .2 After certificate of completion has been issued by authority having jurisdiction.
- .3 Application tolerances:
 - .1 Pressure at fixtures: +/- 70 kPa.
 - .2 Flow rate at fixtures: +/- 20%.
- .4 Adjustments:
 - .1 Verify that flow rate and pressure meet design criteria.
 - .2 Make adjustments while flow rate or withdrawal is (1) maximum and (2) 25% of maximum and while pressure is (1) maximum and (2) minimum.
- .5 Floor drains:
 - .1 Verify operation of trap seal primer.
 - .2 Prime, using trap primer. Adjust flow rate to suit site conditions.
 - .3 Check operations of flushing features.
 - .4 Check security, accessibility, removeability of strainer.
 - .5 Clean out baskets.
- .6 Vacuum breakers, backflow preventers, backwater valves:
 - .1 Test tightness, accessibility for O&M of cover and of valve.
 - .2 Simulate reverse flow and back-pressure conditions to test operation of vacuum breakers, backflow preventers.
 - .3 Verify visibility of discharge from open ports.
- .7 Roof drains:
 - .1 Check location at low points in roof.
 - .2 Check security, removeability of dome.
 - .3 Adjust weirs to suit actual roof slopes, meet requirements of design.
 - .4 Clean out sumps.
 - .5 Verify provisions for movement of roof systems.
- .8 Access doors:
 - .1 Verify size and location relative to items to be accessed.
- .9 Cleanouts:
 - .1 Verify covers are gas-tight, secure, yet readily removable.
- .10 Water hammer arrestors:

Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001

Section 22 42 01 – Plumbing Specialties and Accessories

Page 10 of 10

- .1 Verify proper installation of correct type of water hammer arrester.
- .11 Wall, Ground hydrants:
 - .1 Verify complete drainage, freeze protection.
 - .2 Verify operation of vacuum breakers.
- .12 Pressure regulators, PRV assemblies:
 - .1 Adjust settings to suit locations, flow rates, pressure conditions.
- .13 Strainers:
 - .1 Clean out repeatedly until clear.
 - .2 Verify accessibility of cleanout plug and basket.
 - .3 Verify that cleanout plug does not leak.
- .14 Hose bibbs, sediment faucets:
 - .1 Verify operation and at all low points.
- .15 Commissioning Reports:
 - .1 In accordance with Division 01.
- .16 Training:
 - .1 In accordance with Division 01.
 - .2 Demonstrate full compliance with Design Criteria.