

---

**Washroom Buildings Recapitalization**  
**Buildings 32, 34 & 38**  
**Newman Sound Campground**  
**Terra Nova National Park, NL**  
**Proj. No.: R.079272.001**  
Section 26 50 00 – Lighting

---

Page 1 of 4

**PART 1**      **GENERAL**

**1.1**            **REFERENCES**

- .1 American National Standards Institute (ANSI)
  - .1 ANSI C82.1, Electric Lamp Ballasts-Line Frequency Fluorescent Lamp Ballast.
  - .2 ANSI C82.4, Ballasts for High-Intensity-Discharge and Low-Pressure Sodium Lamps.
- .2 American National Standards Institute/Institute of Electrical and Electronics Engineers (ANSI/IEEE)
  - .1 ANSI/IEEE C62.41, Surge Voltages in Low-Voltage AC Power Circuits.
- .3 American Society for Testing and Materials (ASTM)
  - .1 ASTM F1137, Specification for Phosphate/Oil and Phosphate/Organic Corrosion Protective Coatings for Fasteners.
- .4 United States of America, Federal Communications Commission (FCC)
  - .1 FCC (CFR47) EM and RF Interference Suppression.

**1.2**            **RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 45 00 - Quality Control.

**1.3**            **SUBMITTALS**

- .1 Submit complete photometric data prepared by independent testing laboratory for luminaires where specified, for review by Owner's Representative.
- .2 Photometric data to include: VCP Table and spacing criterion and luminaire coefficient of utilization (CU) tables.
- .3 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .4 Quality assurance submittals: provide the following in accordance with Section 01 45 00 - Quality Control.
  - .1 Manufacturer's instructions: provide manufacturer's written installation instructions and special handling criteria, installation sequence, cleaning procedures and relamping schedule.

---

**Washroom Buildings Recapitalization**  
**Buildings 32, 34 & 38**  
**Newman Sound Campground**  
**Terra Nova National Park, NL**  
**Proj. No.: R.079272.001**  
Section 26 50 00 – Lighting

---

Page 2 of 4

**1.4 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Divert unused metal materials from landfill to metal recycling facility.
- .4 Disposal and recycling of fluorescent lamps as per local regulations.
- .5 Disposal of old PCB filled ballasts.

**1.5 ACCEPTABLE PRODUCTS**

- .1 Luminaires described in the Lighting Fixture Schedule identify quality, performance criteria and other parameters, as indicated for this project. Named fixtures are acceptable with modifications and accessories, as indicated.
- .2 Fixtures from other manufacturers may be acceptable provided:
  - .1 Appearance and lighting performance are similar.
  - .2 Quality is equal or better.
  - .3 Lamp and ballast criteria remain the same.
  - .4 The fixture is provided with modifications and accessories to provide a complete product in keeping with the intent of the project.
  - .5 Approval in writing is obtained from the Owner's Representative to the supplier/manufacturer 5 days prior to tender closing date.

**PART 2      PRODUCTS**

**2.1 LAMPS**

- .1 Fluorescent lamps to be - T8, 32 Watt, medium bi-pin, high performance, energy efficient, instant start, 4100 K, 30,000 hour lamp life, 2950 initial lumens, CRI 80; or as indicated.
- .2 Compact fluorescent lamps to be - 26 Watt, 12,000 hour lamp life, 12,000 initial lumens, 4100 K, CRI 80; or as indicated.

**2.2 BALLASTS**

- .1 Fluorescent ballast: CBM and CSA certified, high performance, energy efficient type, IC electronic.

---

**Washroom Buildings Recapitalization**  
**Buildings 32, 34 & 38**  
**Newman Sound Campground**  
**Terra Nova National Park, NL**  
**Proj. No.: R.079272.001**  
Section 26 50 00 – Lighting

---

Page 3 of 4

- .1 Rating: 120 V, 60 Hz, as indicated, for use with 2-32W, T8 octron imperial lamps.
- .2 RFI/EMI suppression circuit to: FCC (CFR47) Part 18, sub-part C, Class A and Part 15, sub-part B, Class B.
- .3 Totally encased and designed for 40 °C ambient temperature.
- .4 Power factor: minimum 98 % with 98% of rated lamp lumens.
- .5 Crest factor: 1.5 maximum.
- .6 Capacitor: thermally protected.
- .7 Thermal protection: non-resettable on coil.
- .8 Harmonics: 10 % maximum THD.
- .9 Operating frequency of electronic ballast: 20 khz minimum.
- .10 Total Circuit Power: 62 Watts.
- .11 Ballast Factor: greater than 0.90.
- .12 Sound rated: Class A.
- .13 Mounting: integral with luminaire.
- .14 Be warranted by manufacturer for five years.

**2.3 FINISHES**

- .1 Light fixture finish and construction to meet ULC listings and CSA certifications related to intended installation.

**2.4 LUMINAIRES**

- .1 As indicated in luminaire schedule on drawings. Provide 10% spare lamps and 10% spare ballast of each type noted in luminaire schedule.

**2.5 OPTICAL CONTROL DEVICES**

- .1 As indicated in luminaire schedule on drawings.

**PART 3 EXECUTION**

**3.1 INSTALLATION**

- .1 Locate and install luminaires as indicated. Install lamps in all fixtures.
  - .1 Provide adequate support to suit ceiling system.

**3.2 WIRING**

- .1 Connect luminaires to lighting circuits.

---

**Washroom Buildings Recapitalization**  
**Buildings 32, 34 & 38**  
**Newman Sound Campground**  
**Terra Nova National Park, NL**  
**Proj. No.: R.079272.001**  
Section 26 50 00 – Lighting

---

Page 4 of 4

- .1 Install flexible conduit for vertical power supply drop to luminaires as indicated.  
Horizontal wiring using flexible conduit is not permitted.

**3.3 LUMINAIRE SUPPORTS**

- .1 For suspended ceiling installations support luminaires from ceiling grid in accordance with local inspection requirements.

**3.4 LUMINAIRE ALIGNMENT**

- .1 Align luminaires mounted in continuous rows to form straight uninterrupted line.
- .2 Align luminaires mounted individually parallel or perpendicular to building grid lines.

**3.5 FIELD QUALITY CONTROL**

- .1 Perform tests in accordance with Section 26 05 00 – Common Work Results - Electrical and Division 01.

**END OF SECTION**