
**Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001**

Section 22 13 18 – Drainage Waste and Vent Piping – Plastic

Page 1 of 3

PART 1 **GENERAL**

1.1 **SUMMARY**

- .1 Section includes:
 - .1 The installation of drainage waste and vent piping – plastic.

1.2 **RELATED SECTIONS**

- .1 Section 01 35 28 - Health and Safety Requirements.
- .2 Section 23 05 05 - Installation of Pipework.

1.3 **REFERENCES**

- .1 American Society for Testing and Materials (ASTM)
 - .1 ASTM D2235, Specification for Solvent Cement for Acrylonitrille-Butadiene-Styrene (ABS) Plastic Pipe and Fittings.
 - .2 ASTM D2564, Specification for Solvent Cements for Poly(Vinyl-Chloride) (PVC) Plastic Piping Systems.
- .2 Canadian Standards Association (CSA)
 - .1 CSA-B1800 Series, ABS Drain, Waste and Vent Pipe and Pipe Fittings.
 - .2 CSA-B181.2, PVC Drain, Waste and Vent Pipe and Pipe Fittings.
 - .3 CSA-B182.1, Plastic Drain and Sewer Pipe and Pipe Fittings.
- .3 Underwriters Laboratory of Canada (ULC)
 - .1 CAN/ULC-S102.2 Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings, and Miscellaneous Materials and Assemblies.

1.4 **DELIVERY STORAGE AND DISPOSAL**

- .1 Waste Management and Disposal:
 - .1 Separate and recycle waste materials in accordance with Division 01.
 - .2 Collect and separate for disposal, paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.

1.5 **SUBMITTALS**

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit product data for following: valves.

**Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001**

Section 22 13 18 – Drainage Waste and Vent Piping – Plastic

Page 2 of 3

- .3 Submit WHMIS MSDS - Material Safety Data Sheets.
- .4 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
- .5 Submit all unique fire stop listing diagrams.

PART 2 PRODUCTS

2.1 PIPING AND FITTINGS

- .1 For buried DWV piping to:
 - .1 CSA-B181.1.
 - .2 CSA-B181.2.
 - .3 CSA-B182.1.
- .2 For aboveground DWV piping for non-combustible construction, except vertical services shafts and downstream of kitchen equipment:
 - .1 Flame spread rating less than 25 and smoke developed classification less than 50.
 - .2 CSA B181.2
 - .3 Third party certified to CAN/VLC S102.2

2.2 JOINTS

- .1 Solvent weld for PVC: to ASTM D2564.
 - .1 NPS 1 ½ to 6: one step or two step cement
 - .2 NPS 8 and above: two step cement.
- .2 Solvent weld for ABS: to ASTM D2235.

2.3 FIRE STOPS

- .1 At. All fire rated penetrations provide ULC listed firestop systems as per ULC/CAN S115.
- .2 Firestop to be selected to suit piping material and base wall material to meet assembly rating.

**Washroom Buildings Recapitalization
Buildings 32, 34 & 38
Newman Sound Campground
Terra Nova National Park, NL
Proj. No.: R.079272.001**

Section 22 13 18 – Drainage Waste and Vent Piping – Plastic

Page 3 of 3

PART 3 **EXECUTION**

3.1 **INSTALLATION**

- .1 In accordance with Section 23 05 05 - Installation of Pipework and certified journeyperson.
- .2 Install in accordance with National Plumbing Code and local authority having jurisdiction.

3.2 **TESTING**

- .1 Pressure test buried systems before backfilling in accordance with National Plumbing Code.
- .2 Hydraulically test to verify grades and freedom from obstructions.

3.3 **PERFORMANCE VERIFICATION**

- .1 Cleanouts:
 - .1 Ensure accessible and that access doors are correctly located.
 - .2 Open, cover with linseed oil and re-seal.
 - .3 Verify cleanout rods can probe as far as the next cleanout, at least.
- .2 Test to ensure traps are fully and permanently primed.
- .3 Ensure fixtures are properly anchored, connected to system and effectively vented.
- .4 Affix applicable label (sanitary, vent, pump discharge etc.) c/w directional arrows.
- .5 Provide copies of test reports for Commissioning Manuals.

END OF SECTION