



Parks
Canada

Parcs
Canada



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title:

Cameron Day Use Area Rehabilitation – Waterton Lakes National Park

Solicitation No.: / N° de l'invitation :

5P420-16-5025/A

Amendment No.: / N° de modification de l'invitation :

003

Date:

May 6, 2016

Date :

6 mai 2016

GETS Reference No.: / N° de référence de SEAG :

PW-16-00728731

Solicitation Closes: / L'invitation prend fin :

At:

02:00 PM

On:

May 10, 2016

Time Zone:

Mountain Daylight Time (MDT)

À :

14h00

Le :

10 mai 2016

Fuseau horaire :

Heure avancée des Rocheuses
(HAR)

Address Inquiries to: / Adresser toute demande de renseignements à :

Nicole Levesque-Welch

Telephone No.: / N° de téléphone :

(403) 292-4691

Fax No.: / N° de télécopieur :

(403) 292-4475

Email Address: / Courriel :

[nicole.levesque-
welch@pc.gc.ca](mailto:nicole.levesque-welch@pc.gc.ca)

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur

Address - Adresse

Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur

Title - Titre

Signature

Date



This amendment 003 is being raised to respond to questions submitted in response to solicitation 5P420-16-5025/A.

A. QUESTIONS AND ANSWERS

Q1. In regards to the stockpile of Asphalt millings. It States that the millings are to be incorporated into the subgrade. What is the allowable limit to mix the millings into the subgrade?

A1. Millings are to be mixed in to the supplied subgrade gravels to provide a uniform homogeneous material. All millings will be incorporated in to the subbase gravel.

Q2. It also states that there are designated stockpile areas in the specifications but there are none associated with the drawings.

A2. Contractor is to stockpile millings in the work area. No separate designated stockpile outside of the work limits has been defined.

All other terms and conditions remain the same.