

PART 1 GENERAL

- | | |
|--|--|
| <u>1.1 GENERAL</u> | <p>.1 This section describes the extent of services to be provided for wiring of equipment supplied by others.</p> <p>.2 Within the context of this section, Others means:</p> <ul style="list-style-type: none">.1 Other divisions of this specification (i.e.: Division 25 - Integrated Automation)..2 The Owner, as defined in the Contract..3 Other contractors supplying and installing equipment to the contract. |
| <u>1.2 EXTENT OF SERVICES PROVIDED</u> | <p>.1 The work of this contract is to include all power and control wiring of equipment which is provided by Division 26.</p> <p>.2 All power and control wiring above 50 V for equipment supplied by Divisions 21-23 will be the responsibility of this contractor.</p> <p>.3 All control wiring 50 V and less for equipment supplied by Divisions 21 - 23 will be the responsibility of Divisions 21 - 23. Conduit and wire associated with this is the responsibility of Divisions 21 - 23.</p> <p>.4 All power and control wiring associated with equipment supplied by Division 01 will be the responsibility of this contractor. Coordinate with general contractor for exact requirements.</p> <p>.5 Final connection of all wiring to equipment provided by others (except control wiring below 50 V will be by division 26. Coordinate with the provider for connection instructions.</p> |
| <u>1.3 RESPONSIBILITY OF DIVISION 26</u> | <p>.1 It is the responsibility of the Division 26 subcontractor to verify final requirements for wiring of all equipment noted. Verification of wiring requirements to include:</p> <ul style="list-style-type: none">.1 Confirmation of electrical characteristics..2 Location of connection point..3 Method of connection (i.e. direct or plug-in etc.) <p>.2 Obtain and become familiar with shop drawings for all relevant equipment.</p> |

1.3 RESPONSIBILITY .3 No claim for extra will be entertained for wiring
OF DIVISION 26 equipment which has been indicated, or changes to
(Cont'd) installed wiring where installation proceeded prior
to verification of electrical requirements.

PART 2 PRODUCTS

2.1 NOT APPLICABLE .1 Not Applicable

PART 3 EXECUTION

3.1 NOT APPLICABLE .1 Not Applicable