

PART 1 - GENERAL

- |  |  |
|--|--|
| <u>1.1 REFERENCES</u>                          | <ul style="list-style-type: none"><li>.1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)<ul style="list-style-type: none"><li>.1 Material Safety Data Sheets (MSDS).</li></ul></li><li>.2 National Fire Protection Association (NFPA)<ul style="list-style-type: none"><li>.1 NFPA 10-2010, Standard for Portable Fire Extinguishers.</li></ul></li></ul>   |
| <u>1.2 ACTION AND INFORMATIONAL SUBMITTALS</u> | <ul style="list-style-type: none"><li>.1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.</li><li>.2 Product Data:<ul style="list-style-type: none"><li>.1 Submit manufacturer's printed product literature and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.</li><li>.2 Submit one copy WHMIS MSDS - Material Safety Data Sheets.</li></ul></li><li>.3 Provide shop drawings.</li><li>.4 Quality control submittals: submit following in accordance with Section 01 10 10 - General Instructions.<ul style="list-style-type: none"><li>.1 Manufacturer's Instructions: submit manufacturer's installation instructions and special handling criteria, installation sequence, and cleaning procedures.</li></ul></li><li>.5 Closeout Submittals:<ul style="list-style-type: none"><li>.1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.</li></ul></li></ul> |
| <u>1.3 DELIVERY, STORAGE AND HANDLING</u>      | <ul style="list-style-type: none"><li>.1 Packing, shipping, handling and unloading:<ul style="list-style-type: none"><li>.1 Deliver, store and handle materials in accordance with Section 01 10 10 - General Instructions.</li></ul></li><li>.2 Waste Management and Disposal:<ul style="list-style-type: none"><li>.1 Separate waste materials for reuse and recycling in accordance with Section 01 10 10 - General Instructions.</li></ul></li></ul>   |
-

PART 2 - PRODUCTS

2.1 MULTI-PURPOSE DRY CHEMICAL EXTINGUISHERS .1 Stored pressure rechargeable type with hose and shut-off nozzle, ULC labelled for A, B and C class protection. 2A5BC rating.  
.1 Size 2.25 kg.

2.2 IDENTIFICATION .1 Identify extinguishers in accordance with recommendations of ANSI/NFPA 10.  
.2 Attach tag or label to extinguishers, indicating month and year of installation. Provide space for service dates.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS .1 Compliance: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION .1 Install or mount extinguishers on brackets as indicated.