



ADDENDUM # 3

Solicitation Number: 16-2020

Title: 16-2020 FIRE ALARM MONITORING SERVICES

Date: May 6, 2016

The following supplements and/or supersedes the Invitation to Tender documents issued on April 27, 2016. This addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. Any change to the cost of the work as a result of this addendum is to be included in the price proposal. The following revisions supersede the information contained in the original Invitation to Tender Package for the above-mentioned project to the extent referenced and shall become part thereof.

Q & A

Q2. Will the cellular GSM units be released or do we need to account for replacement units?

A2. The winning bidder will be responsible to supply the required cellular backup system as per the specification and code requirements.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

End of Addendum #3