



# TENDER AMENDMENT

**RETURN BIDS TO:**

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3  
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

**Issuing Office:**

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3

# MODIFICATION D'APPEL D'OFFRES

**RETOURNER LES SOUMISSIONS À :**

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300,  
Calgary, AB T2P 3M3  
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Bureau de distribution :**

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300  
Calgary (AB) T2P 3M3

<b>Title:</b> Cameron Day Use Area Rehabilitation – Waterton Lakes National Park		
<b>Solicitation No.: / N° de l'invitation :</b> 5P420-16-5025/A	<b>Amendment No.: / N° de modification de l'invitation :</b> 004	<b>Date:</b> May 9, 2016  <b>Date :</b> 9 mai 2016
<b>GETS Reference No.: / N° de référence de SEAG :</b> PW-16-00728731		
<b>Solicitation Closes: / L'invitation prend fin :</b>		
<b>At:</b> 02:00 PM	<b>On:</b> May 10, 2016	<b>Time Zone:</b> Mountain Daylight Time (MDT)
<b>À :</b> 14h00	<b>Le :</b> 10 mai 2016	<b>Fuseau horaire :</b> Heure avancée des Rocheuses (HAR)
<b>Address Inquiries to: / Adresser toute demande de renseignements à :</b> Nicole Levesque-Welch		
<b>Telephone No.: / N° de téléphone :</b> (403) 292-4691	<b>Fax No.: / N° de télécopieur :</b> (403) 292-4475	<b>Email Address: / Courriel :</b> <a href="mailto:nicole.levesque-welch@pc.gc.ca">nicole.levesque-welch@pc.gc.ca</a>
<b>TO BE COMPLETED BY THE BIDDER (type or print)</b>		
<b>Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur</b>		
<b>Address - Adresse</b>		
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>		
<b>Title - Titre</b>		
<b>Signature</b>		<b>Date</b>



This amendment 004 is being raised to respond to questions submitted in response to solicitation 5P420-16-5025/A.

## A. QUESTIONS AND ANSWERS

Q3. Will we be able to draw water from Cameron lake creek or do we have to get water from the townsite?

A3. Yes, water withdrawal from Cameron Lake is permissible under the conditions of a restricted activity permit. Please review the relevant environmental mitigations that are included in Table G-1 of the BIA (specifically alteration of fish habitat, destruction of fish habitat, introduction of aquatic invasives, water intakes etc.)

Q4. The spec says no equipment in the water is allowed. Can we use a boat in the water to install the screw piles?

A4. Yes. Please review the relevant environmental mitigations that are included in Table G-1 of the BIA (specifically alteration of fish habitat, destruction of fish habitat, introduction of aquatic invasives, etc.)

Q5. Do you have a location that we can store topsoil in the park to be hauled back in to the site later?

A5. Yes. The Park will work with the contractor to identify topsoil storage locations within WLNP. Depending on the the locations, topsoil storage locations will be subject to operational conditions (e.g., keeping soil within defined boundaries, providing records of soil quantity and source to PCA).

Q6. Is Jim Garners Pit an approved disposal site for asphalt or concrete?

A6. Disposal must be in a provincially approved pit.

Q7. On the Trail Construction (C19- 2.22) there is no specs to what this trail is to look like for a structure (Asphalt, Gravel Etc) there is also the adjustment of this path. Should there be a removal price?

A7. No it is paid for under common excavation

Q8. In regards to the stockpile of Asphalt millings. It states that the millings are to be incorporated into the subgrade. What is the allowable limit to mix the millings into the subgrade? It also states that there are designated stockpile areas in the specs but there are none associated with the drawings.

A8. Millings are to be mixed in to the supplied subgrade gravels to provide a uniform homogeneous material. All millings will be incorporated in to the subbase gravel.

Contractor is to stockpile millings in the work area. No separate designated stockpile outside of the work limits has been defined.

Q9. During the site visit, the PM mentioned that the trees had to be hauled away. However, he did not have a tree count. Are you now aware of how many trees have been cut down?

A9. Trees have been removed by PCA. The Contractor is required to remove brush, including small limbs and tree bases (roots) only.

Q10. The Akimina highway will be radio controlled during construction with strict protocol in place during use. IE equipping each vehical with radios and having them read out every mile marker. Is this for the duration of the project or only during the paving of the highway starting September 1?

A10. Radio controls will be in place for the duration of the Project.

Q11. Please confirm whether a hazardous material survey has been completed for this project.

A11. Yes a survey has been completed. No hazardous materials have been identified.

**All other terms and conditions remain the same.**