



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet Construction Cape Sable Lighthouse	
Solicitation No. - N° de l'invitation EB144-162807/A	Amendment No. - N° modif. 011
Client Reference No. - N° de référence du client EB144-16-2807	Date 2016-05-10
GETS Reference No. - N° de référence de SEAG PW-\$PWA-124-5394	
File No. - N° de dossier PWA-6-76002 (124)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-05-12	
Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Matheson (PWA), Valerie	Buyer Id - Id de l'acheteur pwa124
Telephone No. - N° de téléphone (902) 496-5100 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EB144-162807/A

Amd. No. - N° de la modif.
011

Buyer ID - Id de l'acheteur
PWA124

Client Ref. No. - N° de réf. du client
EB144-16-2807

File No. - N° du dossier
PWA-6-76002

CCC No./N° CCC - FMS No/ N° VME

Amendment 0011

Due to the technical nature of Amendment 0011 it will be available in ENGLISH only.

Amendment 0011 is raised to incorporate the following change.

Specification - Section 08 80 50 - GLAZING - page 3

Delete in its entirety LINE ITEM 2.01.1.1 and replace with the following:

Size glass to withstand wind loads, dead loads and positive and negative live loads acting normal to plane of glass to design pressure of 300Pa for driving wind pressures in accordance with the NBC Division B, Table C-2 – Design Data for Selected Locations in Canada.

Delete in its entirety LINE ITEM 2.01.2.1 and replace with the following:

Provide 12mm thick, tempered, laminated, low iron glass with a 1.5mm ultra clear PVB interlayer. 88% light transmittance or greater.

All other terms and conditions remain the same.