



ADDENDUM # 4

Solicitation Number: 16-2020

Title: 16-2020 FIRE ALARM MONITORING SERVICES

Date: May 10, 2016

The following supplements and/or supersedes the Invitation to Tender documents issued on April 27, 2016. This addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. Any change to the cost of the work as a result of this addendum is to be included in the price proposal. The following revisions supersede the information contained in the original Invitation to Tender Package for the above-mentioned project to the extent referenced and shall become part thereof.

Q & A

Q3. Will the installer (programmer) codes be provided to the winning bidder?

A3. Yes, the installer (programmer) codes will be made available to the winning bidder upon contract award.

Q4 What is the current monitoring equipment on site?

A4 The monitoring equipment on site is:

- KIT32-412HC Fire Monitoring System
- HSPA Wireless Alarm Communicator 3G2060R
- Keypad PK series
- Power Series v4.6 Control Panel
- Internet/Intranet Communicator TL260R

Q5 Is the monitoring equipment owned by Agriculture and Agri-Food Canada

A5 Yes the monitoring equipment is owned by Agriculture and Agri-Food Canada.

Q6 Is the equipment considered ULC qualified without a conduit for the CAT 5 cable?

A6 Yes, this is considered ULC qualified.

Q7 Is the pricing to include a full service contract or fire alarm monitoring only?

A7 The pricing is for the work captured under the statement of work, fire alarm monitoring.

Q8 Page 34 states:
Provide central monitoring services for the following twenty-eight (28) buildings in accordance with CAN/ULC-S561, "Standard for Installation and Services for Fire Signal Receiving Centers and Systems," 2013 edition".

- Building's 12, 18, 19, 20, 21, 22, 34, 49, 50, 55, 57, 59, 72, 74, 75, 76, 88, 91, 94, 95, 97, 99, 106, 110, 114, 143, 148, 151.

– is a ULC Certificate required for each building?

A8 Yes, a ULC Certificate is required for all buildings.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

End of Addendum #4