



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

001

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Cameron Falls & Bay Washrooms Waterton Lakes National Park		
Solicitation No. - No. de l'invitation 5P420-16-5056/A		Date: May 12, 2016
GETS Reference No. - No de reference de SEAG PW-16-00731477		Amendment No. - N° de la modif. 001
Solicitation Closes:		
at - à 02:00 PM	on - le May 24, 2016	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :		
Jen Maheu		
Telephone No. - No de téléphone		Fax No. - No de FAX:
(403) 292-8502		(403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 01

This amendment is being raised to distribute answers to bidder questions submitted by email and provide clarifications on the project scope.

A. BIDDER QUESTIONS & CLARIFICATIONS

Q1 Should a Tyvek c/w tape method be used for the air barrier?

A1 Yes

Q2 Should soap dispensers and coat hooks be supplied for Cameron Falls Bathroom?

A2 Yes

Q3 Should the Contractor supply four additional paper towel dispensers?

A3 Yes

Q4 What type of exterior sealant is to be used?

A4 Lepages Quad or equivalent.

Q5 Are toilet partitions to be metal or phenolic black core?

A5 Partitions are to be phenolic black core with 19mm thick doors and pilasters and 13mm panels. They are to be floor braced pilasters.

Q6 Can substitutions be made to partition models?

A6 Contractors are to bid to existing specs.

Q7 Should the interior window and door trim paint specs to be the same spec as interior wall paint specs?

A7 Yes

Q8 Should the roof underlayment be synthetic paper?

A8 Yes

Q9 What are landscaping requirements?

A9 Repair all disturbed areas as follows

(1) Remove excess fill from Parks property. (2) Rough grade to be 138mm below sidewalks sloped to 100mm below existing grades. (3) Finish with salvaged native top soil or imported topsoil to 38mm below sidewalks and flush to existing grade. (4) Seed with lawn seed. (5) Parks Representative and Consultant to approve slope and shape design and soils.

Q10 Should the contractor supply connecting sidewalks?

A10 Yes, the contractor will supply an additional 28M2 of 100mm thick sidewalk c/w 10mm reinforcement at 400mm EW on prepared gravel base. This will connect the buildings to existing sidewalks.

Q11 Should column footings be the same depth as the building foundation?

A11 Yes, and cover the footings with 50mm Styrofoam SM to 1200mm all around.

Q12 Are bollards required at the Falls Washroom?

A12 No

Q13 Are curb stop water shut offs required at both buildings?

A13 No Parks have supplied them.

Q14 Should contractors supply exterior sanitary cleanouts to grade and connections to existing 150mm sanitary?

A14 Yes

Q15 Are two conduits required for electrical supply?

A15 No, one only.

Q16 Is an electrical meter required at Bay Washroom?

A16 No

Q17 Does the Contractor supply the building permit?

A17 No, Parks will supply.

Q18 Does the Contractor supply concrete and compaction testing?

A18 No, Parks will supply.

Q19 Will Parks require separate invoicing, billing schedule and change orders for the two buildings?

A19 Yes

Q20 Can Parks supply elevation benchmarks and reference lines?

A20 Yes

Q21 What are soil conditions?

A21 The construction areas are part of an alluvial plane consisting of glacial till. Rock to 300mm and boulders to one M can be encountered. Parks recent experience in excavation in the general areas has been positive.

All other terms and conditions remain unchanged.