

ADDENDUM NUMBER: ONE

ISSUED BY: SEPW Architecture Inc.
109 – 3725 Pasqua St., Regina, SK. S4S 6W8
PH. (306) 569-2255

**PROJECT: INTERIOR FIT-UP
REGINA, SASKATCHEWAN**

This Addendum forms part of the Contract Documents and amends the original Drawings and Specifications dated 2016-03-11, previous Addenda if applicable and as noted below. This Addendum consists of 1 pages and attached Specification Sections and Drawings as listed below.

Ensure that all parties are aware of all items included in this Addendum.

The following revised or additional Specification Sections accompany and form an integral part of this Addendum:

Section No.	Title	Pages	Date of Issue
	N/A		

The following revised or additional Drawings accompany and form an integral part of this Addendum:

Dwg. No.	Title	Date of Issue
	N/A	

A-1-1 REF. SECTION 09 65 16 - RESILIENT FLOORING

2.1.1 Delete: Material description - Resilient Safety Flooring

A-1-2 REF. SPECIFICATIONS SECTION 26 50 00 – LIGHTING

2.5.14 Revise: Fixture type 'F' – The Lumens output from 5400 to a minimum of 862 Lumens.

A-1-3 REF. SPECIFICATIONS SECTION 28 31 01 – FIRE ALARM SYSTEMS

1.5.1 The operation of the existing 2-stage addressable fire alarm system shall be revised. The fire alarm system shall be re-programmed to provide zero delay between the pre-signal alert and alarm stage, such that the fire alarm system operates as a single stage system.

A-1-4 REF. DRAWING E1.1 - MAIN FLOOR LIGHTING PLAN

.1 Reference Room 152: The exterior housing for the six (6) type 'AA' fixtures in this room shall be factory painted matte black. All other type 'AA' fixtures shall be painted as specified in Section 26 50 00.

END OF ADDENDUM NO. 1