



Royal Canadian Mounted Police
Gendarmerie royale du Canada

RETURN BIDS TO :

RETOURNER LES SOUMISSIONS :

Bid Receiving Unit / Grope de la réception des soumissions

Procurement and Contracting Services
 73 Leikin Drive,
 Visitor Center - Building M1
 Mailstop # 15
 Ottawa, ON K1A 0R2

Attn: Shannon Plunkett (613) 843-3798

AMENDMENT TO THE INVITATION TO TENDER

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

MODIFICATION À L'APPEL D'OFFRES

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté l Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telephone No. – No de téléphone:

()

Facsimile No. – No de télécopieur:

()

Title-Sujet Construction – Renovation – Forensic Laboratory Regina		
Solicitation No. – No. de l'invitation 201700501	Amend. – Modif. No. : 3	Date May 17th, 2016
Client Reference No. - No. de Référence du Client 201700501		
GETS Reference No. – No de Référence du SEAG 201700501		
Solicitation Closes – L'invitation prend fin at - à 2 :00 pm ET on - le May 31st, 2016		
F.O.B. - F.A.B. Destination		
Address Enquiries to: - Adresser toute questions à : Penny Maillard – Senior Contracting Officer penny.maillard@rcmp-grc.gc.ca		
Telephone No. - No de téléphone 613-843-5518	Fax: 613-825-0082	
Destination of Goods - Destinations des biens: See Herein		
Instructions : See Herein / Voir aux présentes		
Delivery Required – Livraison exigée: See Herein		
Name and Title of person authorized to sign on behalf of Vendor/Firm. Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Amendment #3 of Solicitation 201700501 has been issued to respond to **Questions and Answers – Part 1**, respond to **Request for Alternatives Products and/or Materials – Part 1**, and to issue **Addendum #1** for this requirement.

Questions and Answers – Part 1:

Q1: Sheet A0.0, new fixed transom for F3 – please advise dimensions. We require this for the glass pricing.

A1: *The new fixed transoms are to be the same construction as their respective doors and provide the same rating as the doors in each location. Reference revised Section 08 90 10 Door, Frame and Hardware Schedule.*

Door No.	Door				Frame			Rating (Min.)	Glass	Additional Requirements
	Size	Type	Mat'l	Fin.	Type	Mat'l	Fin.			
Main Floor – Refer to Drawing A1.1										
146C	2- 900 x 2150	A	HM	PT-	F3	PS	PT-	90 MIN	-	Add horizontal mullion and fixed hollow metal transom. F3 Size: 1800 x 3660 Confirm existing dimensions.
153B	2 – 900 x 2150	A	HM	PT-	F3	PS	PT-	45 MIN	-	Add horizontal mullion and fixed hollow metal transom. F3 Size: 1800 x 3660 Confirm existing frame dimensions.

Q2: Sheet A1.1 - Corner aluminum framing in room 153 - please advise the dimension of the frame that has no dimension

A2: *Glazing dimensions are shown on floor plan 2/A1.1 and detail 7/A5.1.*



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Request for Alternative Products and/or Materials – Part 1:

Request 1: Walt Curilla-Diamond Hard Surfaces (Calgary) Inc.– SureBond Safe Floors

Response 1: *Safety floors are not required for this project; alternate product request not required.*

Request 2 – Derek Csada-Insted Technical Sales– Light Fixtures

Response 2: *Suppliers of approved products are responsible to ensure that the following approved equals fully meet the requirements of the specifications, and that the approved equals do not diminish both the grade of product and appearance to those products specified. The following manufacturers and products listed shall be considered as approved equals to the specified products:*

Specifications Section 26 50 00 Lighting

- i. Type 'BB' – Focal Point Seem 2 FSM2LS Series*
- ii. Type 'BB5' - Focal Point Seem 2 FSM2LS Series*
- iii. Type 'EE' – Philips Day-Brite FluxStream LF4 Series*
- iv. Type 'EE2' – Philips Day-Brite FluxStream LF2 Series*
- v. Type 'FF' – Philips Day-Brite FluxStream LF4 Series*
- vi. Type 'GG' – Focal Point Seem 4 FSM4L Series*
- vii. Type 'F' – Focal Point Skydome FSDL-22 Series, 2000 Lumens, matte black finish*

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.