

ADDENDUM # 1

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

Renovations to AAFC Labs, Research and Development Centre, St. John's, NL

1. Plumbing and Electrical Fittings Clarification:

Any plumbing or electrical fittings normally provided with the casework that are unique to the casework and not commonly available otherwise (which would include for example the sink tail pieces) are to be supplied by the casework manufacturer and provided to the mechanical and electrical contractor for their installation if provided loose. The mechanical contractor shall supply and install sink faucets, drainage and supply piping, emergency eyewash units, and gas turrets as per the relevant specification sections and drawings. Likewise the electrical contractor shall supply and install electrical pedestals, receptacles, power wiring, etc. Holes in casework for installation of mechanical and electrical fittings shall be drilled by casework installer coordinating with the mechanical and electrical sub trades.

2. RO Water System Installation

Reference drawing M3-R0 detail 2. Interconnecting tubing between the RO water system and water reservoir is 6mm and is provided with the system and installed by the contractor. The concentrate drainage and glassware feed tubing is supplied and installed by the contractor. There is no special materials requirements for these tubes. The glassware washer feed tube may also be a stainless steel braided type used for dishwasher or washing machine supply. The contractor shall also supply and install a PVC overflow tube (not indicated in the schematic) from the reservoir to the open funnel drain. There is no special materials requirement for this tubing.

3. Compressed Gas and Vacuum Tubing

Reference specification section 22 15 00 – General Service Compressed Air Systems part 2.1. Compressed gas and vacuum piping to be type K degreased copper.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.