



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

003

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Cameron Falls & Bay Washrooms Waterton Lakes National Park		
Solicitation No. - No. de l'invitation 5P420-16-5056/A		Date: May 20, 2016
GETS Reference No. - No de reference de SEAG PW-16-00731477		Amendment No. - N° de la modif. 003
Solicitation Closes:		
at - à 02:00 PM	on - le May 24, 2016	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :		
Jen Maheu		
Telephone No. - No de téléphone		Fax No. - No de FAX:
(403) 292-8502		(403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 03

This amendment is being raised to distribute the answers to bidder questions submitted by email.

Q1 Can the expandable jamb door frames be 18 gauge steel?

A1 Yes

Q2 Does the contractor supply the conduit for the electrical line under the cul-de-sac?

A2 Parks Canada has installed conduit from the existing lift station panel to within 3M of the Bay Washroom. The contractor is to supply conduit into the new washroom and 75M of conductor to connect the washroom to the lift station.

All other terms and conditions remain unchanged.