



Royal Canadian Mounted Police
Gendarmerie royale du Canada

RETURN BIDS TO :

RETOURNER LES SOUMISSIONS :

Bid Receiving Unit / Grope de la réception des soumissions

Procurement and Contracting Services
 73 Leikin Drive,
 Visitor Center - Building M1
 Mailstop # 15
 Ottawa, ON K1A 0R2

Attn: Shannon Plunkett (613) 843-3798

AMENDMENT TO THE INVITATION TO TENDER

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

MODIFICATION À L'APPEL D'OFFRES

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté I Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telephone No. – No de téléphone:

()

Facsimile No. – No de télécopieur:

()

Title-Sujet Construction – Renovation – Forensic Laboratory Regina		
Solicitation No. – No. de l'invitation 201700501	Amend. – Modif. No. : 5	Date May 20th, 2016
Client Reference No. - No. de Référence du Client 201700501		
GETS Reference No. – No de Référence du SEAG 201700501		
Solicitation Closes – L'invitation prend fin at - à 2 :00 pm EDT on - le May 31st, 2016		
F.O.B. - F.A.B. Destination		
Address Enquiries to: - Adresser toute questions à : Penny Maillard – Senior Contracting Officer penny.maillard@rcmp-grc.gc.ca		
Telephone No. - No de téléphone 613-843-5518	Fax: 613-825-0082	
Destination of Goods - Destinations des biens: See Herein		
Instructions : See Herein / Voir aux présentes		
Delivery Required – Livraison exigée: See Herein		
Name and Title of person authorized to sign on behalf of Vendor/Firm. Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Amendment #5 of Solicitation 201700501 has been issued to respond to **Questions and Answers – Part 2**, respond to **Request for Alternatives Products and/or Materials – Part 2**, and to issue **Addendum #2** for this requirement.

Questions and Answers – Part 2:

Q3 – Will after hours and weekends access be available during this project?

A3 – *Yes, as per Section 01 14 00 Part 1 - 1.1.3 any additional after hours work as requested by the successful contractor will be considered.*

Q4– Is there a phasing plan for this project? Or will the successful GC have access to all areas at once?

A4 – *Yes, Work on main floor is to be completed prior to commencing Work on the second floor. An exception to this will be the relocated cabinets and items from within the second floor work area. Coordination with the User group will be required to ensure minimal disruption. Contractors approach towards phasing plan to be shown on the project schedule.*

Q5– Will all existing furniture & mobile storage shelving be removed from the areas to be renovated prior to GC starting? Or will the GC be responsible for moving/relocating/storing this furniture?

A5 – *The General Contractor will be responsible for the demolition, removal or salvaging of any furniture, free standing items, built in items (such as millwork, cabinets, equipment) in areas of Work.*

The mobile shelving observed during walk-through will be removed by the Owner prior to the start of construction.

Q6– Would the architect please provide the areas (m2 or ft2) for the floor polishing?

A6 – *Reference SK-1 for grid line dimensions to generate area calculations.*



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Q7– Will there be an area designated adjacent to the building for waste/recycling bins, C-can storage & site trailer?

A7 – Yes, an area will be identified once contract is awarded.

Q8– Under BA06, the construction completion date listed is June 30, 2017. Approximately when will the materials in Section 10 56 00 need to be installed?

A8 – The successful Contractor will produce a project schedule detailing the expected timeline for phase one and two of the project; main floor being phase one. It would be expected that all materials in Section 10 56 00 are installed during phase one.

Q9– Regarding Drawing # A4.1; do units MLB6 and MLB7 require a solid panel (a back panel in the middle of the unit) or is it the intent to have them as a pass through double entry unit?

A9 – All mobile shelving units, including MLB6 and MBL7, require a solid back panel.

Q10– Regarding the mobile components that will be installed into the freezer units (Room 155, Units MLB1, MLB2, MLB3, and MLB4) do they require freezer grade components, bearings etc. to withstand cold temperatures – is there a spec anywhere for these materials

A10 – Yes, components within the Room 155 will require freezer grade components for temperatures up to -20°C.

Q11– Regarding the shelving for the above, do you require an anti-microbial graphite industrial epoxy material that is washable and can withstand cold temperatures?

A11 – Shelving should be easily cleanable and composed of materials that can withstand cold temperatures.

Q12– One other question relating to the storage system requirement in the walk-in freezer unit, room # 155: I'm assuming the requirement for the track will be a stainless steel, surface mounted style.

A12 – The system and required components within the freezer room are to be of appropriate materials, while remaining serviceable and operable in temperatures up to -20°C.



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Request for Alternative Products and/or Materials – Part 2:

Request 3 – Candace Hahn-PRIMCO-Flooring & Tile

Response 3 – *Safety floors are not required for this project; alternate product request not required.*

SDT alternate, ROPPE eds Vinyl Static Control Tile is an acceptable alternate.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.