



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions
- TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction

11 Laurier St./11 Rue Laurier

3C2, Place du Portage

Phase III

Gatineau, Québec K1A 0S5

Title - Sujet Brouse/Slater Roof Replacement	
Solicitation No. - N° de l'invitation EP759-162793/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client 20162793	Date 2016-05-25
GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-359-70912	
File No. - N° de dossier fg359.EP759-162793	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-06-07	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Benoit, Marie-Eve	Buyer Id - Id de l'acheteur fg359
Telephone No. - N° de téléphone (819) 420-0720 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: MINISTERE DE TRAVAUX PUBLICS ET SERVICES GOUVERNEMENTAUX / DEPARTMENT OF PUBLIC WORKS AND GOVERNMENT SERVICES EDIFICE BROUSE/SLATER BUILDING 181 RUE SPARKS ST. OTTAWA K1P5B9	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EP759-162793/A

Amd. No. - N° de la modif.

001

Buyer ID - Id de l'acheteur

FG359

Client Ref. No. - N° de réf. du client

20162793

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

THE PURPOSE OF THIS AMENDMENT IS TO ISSUE THE FOLLOWING:

1. Addendum 001 attached.

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.

The following changes in the Bid Documents are effective immediately. This addendum shall form part of the Contract Documents.

DRAWINGS

Drawing M-1 Mechanical Demolition and New

1. Delete drawing M-1 dated 15-03-31 and replace it with the attached drawing M-1 dated 16-05-25 attached hereto.

END OF ADDENDUM

MECHANICAL LEGEND

SYMBOL	DESCRIPTION
— GLYCOL PIPING DEMOLITION	
AH	AIR HANDLER
●	RAIL VALVE
CHL	CHILLER
CWB	CHILLED WATER SUPPLY
CWR	CHILLED WATER RETURN
EX	EXHAUST
●	PUMP
RD	ROOF DRAIN
RTU	ROOFTOP HVAC UNIT
●	VALVE
V	VENT
XT	EXPANSION TANK

GENERAL NOTES

- ARCHITECTURAL BACKGROUNDS ARE REPRESENTATIVE ONLY. ALTHOUGH EVERY EFFORT HAS BEEN MADE TO PREPARE AN ACCURATE SET OF DRAWINGS, THE CONTRACTOR SHALL VERIFY ALL INFORMATION AND CONDITIONS PRIOR TO CONSTRUCTION. FOR ALL FACTORS OF MECHANICAL AND ELECTRICAL DEMOLITION, THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF SAN FRANCISCO AND THE CALIFORNIA DEPARTMENT OF INDUSTRIAL RELATIONS (CDIR).
- ALL EXISTING PIPING AND ELECTRICAL SYSTEMS SHALL BE DEMOLISHED AND REMOVED FROM THE BUILDING. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF SAN FRANCISCO AND THE CALIFORNIA DEPARTMENT OF INDUSTRIAL RELATIONS (CDIR).
- ALL MECHANICAL EQUIPMENT LOCATIONS SHOWN ON ELECTRICAL DRAWINGS SHALL BE DEMOLISHED AND REMOVED FROM THE BUILDING. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF SAN FRANCISCO AND THE CALIFORNIA DEPARTMENT OF INDUSTRIAL RELATIONS (CDIR).
- ALL NEW MATERIAL TO BE CONNECTED TO EXISTING PIPING, DUCTWORK, ACCESSORIES SHALL BE TO MATCH MATERIAL OF EXISTING SYSTEM.

NEW HEATER SCHEDULE

UNIT	MANUFACTURER	MODEL	NOTES	WEIGHT	OPTIONS
UH-2	DAVID	500759	240	750	4.0% INTEGRAL THERMOSTAT

NEW THERMOSTAT SCHEDULE

UNIT	MANUFACTURER	MODEL	NOTES	WEIGHT	OPTIONS
T-1	DAVID	500759	240	750	4.0% INTEGRAL THERMOSTAT

NEW ROOF DRAIN SCHEDULE

ID	MANUFACTURER	MODEL	NOTES	WEIGHT	OPTIONS
RD-1	DAVID	500759	240	750	4.0% INTEGRAL THERMOSTAT

KEY PLAN

EXISTING ROOF - DEMOLITION WORK

CHILLER REMOVAL - FRONT VIEW

TYPICAL DUCT RESTRAINT - SIDE VIEW

CHILLER REMOVAL - FRONT VIEW

TYPICAL DUCT RESTRAINT - FRONT

GROUND FLOOR PLAN

MECHANICAL ROOM 001

BOOTH BUILDING - STORAGE ROOM - DEMOLITION LAYOUT

DRAWING NOTES

- THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF SAN FRANCISCO AND THE CALIFORNIA DEPARTMENT OF INDUSTRIAL RELATIONS (CDIR).
- ALL EXISTING PIPING AND ELECTRICAL SYSTEMS SHALL BE DEMOLISHED AND REMOVED FROM THE BUILDING. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF SAN FRANCISCO AND THE CALIFORNIA DEPARTMENT OF INDUSTRIAL RELATIONS (CDIR).
- ALL MECHANICAL EQUIPMENT LOCATIONS SHOWN ON ELECTRICAL DRAWINGS SHALL BE DEMOLISHED AND REMOVED FROM THE BUILDING. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF SAN FRANCISCO AND THE CALIFORNIA DEPARTMENT OF INDUSTRIAL RELATIONS (CDIR).
- ALL NEW MATERIAL TO BE CONNECTED TO EXISTING PIPING, DUCTWORK, ACCESSORIES SHALL BE TO MATCH MATERIAL OF EXISTING SYSTEM.