



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

INVITATION TO TENDER

APPEL D'OFFRES

AMENDMENT / MODIFICATION

002

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Animal Underpass Bridge Rehabilitation - TCH Km 0.6 and 6.4 Banff National Park		
Solicitation No. - No. de l'invitation 5P420-16-5073/A		Date: May 27, 2016
GETS Reference No. - No de reference de SEAG PW-16-00732661		Amendment No. - N° de la modif. 002
Solicitation Closes:		
at - á 02:00 PM	on - le June 1, 2016	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à : Nathaniel Harrison - nathaniel.harrison@pc.gc.ca		
Telephone No. - No de téléphone (403) 292-4572		Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 2

This amendment has been issued to answer questions from a potential bidder.

A. Questions

- Q2.** “Do you know what dosage of synthetic fibre/m3 they require for the bridge decks? The spec describes the fibre (length, modulus of elasticity, tensile strength), but doesn't provide a dosage. The fibre company has various dosages for different applications.”
- A2.** Specification 03 30 51 Concrete for Bridge Decks is a performance based specification. The supplier shall determine the dosage of fibre required that will provide a concrete mix that satisfies the performance requirements defined in the specification, specifically the Minimum Post-Cracking Residual Strength Index of 0.15. The Residual Strength index and how it is calculated is defined in the Canadian Highway Bridge Design Code (CAN/CSA-S6-14) Clause 16.6.2.

All other terms and conditions remain unchanged.