

1 E01 NEW SITE PLAN
SCALE: 1:250
0m 5m 10m 15m 20m 25m

2 E01 SECTION – CONDUIT IN BEDROCK
SCALE : 1:20
0mm 500mm 1000mm 1500mm 2000mm 2500mm

3 E01 SECTION – TYPICAL CONDUIT TRENCH
SCALE: N.T.S.

Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

GENERAL NOTES:

1. DO NOT SCALE FROM DRAWINGS.
2. ALL DIMENSIONS AND ELEVATIONS ARE IN METERS UNLESS OTHERWISE NOTED.
3. FLOOD LIGHT TO BE 400W PS METAL HALIDE, DIE-CAST ALUMINUM HOUSING, POLYESTER POWDER COATED BRONZE FINISH, FULLY GASKETED DOOR, C/W SLIP FITTER MOUNTING, WIREGUARD. ACCEPTABLE MAT: COOPER WR-MP-65-S-MP400-MT-WG.
4. TYPICAL PULL PIT TO BE HDPE MATERIAL WITH PEDESTRIAN RATED COVER. CARSON 1015 OR EQUIVALENT.

PEGNL Newfoundland and Labrador
REGISTERED PROFESSIONAL ENGINEER
TRACY DOUGLAS
MAY 4, 2016
NEWFOUNDLAND & LABRADOR

PROVINCE OF NEWFOUNDLAND AND LABRADOR
PEGNL Newfoundland and Labrador PERMIT HOLDER This Permit Allows
CBCL LIMITED
To practice Professional Engineering in Newfoundland and Labrador. Permit No. as issued by PEGNL D0178 which is valid for the year 2016.

revisions		date
0	ISSUED FOR TENDER	MAY 4 2016

project / projet
SIGNAL HILL PARKING AREA IMPROVEMENTS

drawing / dessin
NEW ELECTRICAL SITE PLAN

designed / conçu: JACK CAINES
date: APRIL 1, 2015
drawn / dessiné: JONATHAN NICHOLAS
date: APRIL 1, 2015
approved / approuvé
date
Tender / Soumission
PWGSC Project Manager / Administrateur de projets TPSGC 13 May 2016
project number / no. du projet: R.071834.001
drawing no. / no. du dessin: E01

PWGSC B1 (2004)

E-DRM/GDD-E: 531193