

1.1 RELATED WORK

- .1 Section 21 05 01: Mechanical General Requirements.

1.2 DESCRIPTION OF SYSTEMS

- .1 Provide NPS ½ priming lines to floor drain traps as indicated.
- .2 Do all work in accordance with the 2010 Canadian Plumbing Code and the local authorities having jurisdiction.
- .3 All underground drains to be a minimum of NPS 2.
- .4 Maintain a minimum 50mm clearance between finished piping, including insulation.
- .5 Provide piping sleeves for piping penetrating concrete floor slabs.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Collect, separate and recycle all site generated waste materials in accordance with Section 01 74 21 – Construction/Demolition Waste Management and Disposal.

END OF SECTION