

PART 1 - GENERAL

1.1 RELATED WORK

- .1 Section 26 05 00: Electrical General Requirements.
- .2 Section 31 00 99: Earthworks for Minor Works.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not applicable.

PART 3 - EXECUTION

3.1 CABLE INSTALLATION IN DUCTS

- .1 Install cables as indicated in ducts.
- .2 Do not pull spliced cables inside ducts.
- .3 Install multiple cables in duct simultaneously.
- .4 Use CSA approved lubricants of type compatible with cable jacket to reduce pulling tension.
- .5 To facilitate matching of colour coded multiconductor control cables, reel off in same direction during installation.
- .6 Before pulling cable into ducts and until cables are properly terminated; seal ends of cables with moisture seal tape.
- .7 After installation of cables, seal duct ends with duct sealing compound.

END OF SECTION