


PLAN — CONDUIT PLAN THROUGH FOUNDATION WALL **2**
E1.0


SCALE: 1:25
0mm 500mm 1000mm 1500mm 2000mm 2500mm

SEE **2** FOR TYPICAL CONDUIT PENETRATION.



SECTION **A**


SCALE : 1:10
0mm 100 200 300 400 500 600 700 800 900 1000mm




SECTION **B**

SCALE : 1:10
0mm 100 200 300 400 500 600 700 800 900 1000mm

- NOTES:
1. EEMAC 4x S.S. ENCLOSURE AND CONDUITS ARE TO BE PREPARED AND PAINTED WITH EPOXY PAINT TO MATCH BUILDING CLADDING COLOR.
 2. STEEL FRAME TO BE HOT DIPPED GALVANIZED.
 3. ALL CONDUITS EXPOSED TO EXTERIOR ARE TO BE RIGID ALUMINUM.



BACK PLAN



SCHEMATIC

ELEVATION — CUSTOM CONTROL PANEL **1**
E1.0

- NOTE:
1. PROVIDE CSA CERTIFICATION FOR THE COMPLETE CONTROL PANEL ASSEMBLY.