



AMENDMENT #3:

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS
À:**

**Parks Canada Agency
National Contracting Services
Bid Receiving Unit
111, Water Street East
Cornwall ON K6H 6S3**

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
111, Water Street East
Cornwall ON K6H 6S3**

| | | |
|---|---------------------------------|--|
| Title-Sujet Perimeter road rehabilitation and pedestrian access improvements at Halifax Citadel | | |
| Solicitation No. - No. de l'invitation 5P300-16-5083/A | | Date: June 02, 2016 |
| GETS Reference No. - No de reference de SEAG PW-16-00733277 | | Client Ref. No. - No. de réf du client. |
| Solicitation Closes: | | |
| at - à 02:00 PM | on - le June 07, 2016 | Time Zone - Fuseau horaire EDT - HAE |
| F.O.B. - F.A.B. | | |
| Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/> | | |
| Address Inquiries to: - Adresser toute demande de renseignements à : Patrick Alguire – patrick.alguire@pc.gc.ca | | |
| Telephone No. - No de téléphone (613) 938-5955 | | Fax No. - No de FAX: |
| Destination of Goods, Services, and Construction: Destinations des biens, services et construction: | | |
| See Herein – Voir ici | | |

**TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)**

| | |
|--|-------------|
| Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur | |
| Address - Adresse | |
| Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur | |
| Titale - Titre | |
| Telephone No. - N° de téléphone: _____ | |
| Facsimile No. - N° de télécopieur: _____ | |
| Email - Courriel: _____ | |
| Signature | Date |

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

1. Revised Specifications

See DSP 3 - 5P300-16-5083A.zip for all revisions to the specifications document.

Summary of the changes:

In: DSP 1 - 5P300-16-5083A.zip,
Halifax Citadel - Perimeter Road Renewal, Issued for Tender, PCA 734.pdf
Section, Part: 01 14 00 – Work Restrictions, Item 1.3 Use of Site and Facilities

Add:

.5 On Tuesday, July 12, 2016 there is a special event planned at the Halifax Citadel and the Contractor will not be permitted to complete any work on site. The site must be cleared and all required safety measures for the public must be in place. The entire perimeter road must be accessible for vehicle traffic

In: DSP 1 - 5P300-16-5083A.zip,
Halifax Citadel - Perimeter Road Renewal, Issued for Tender, PCA 734.pdf
Section, Part: 01 29 00 – Payment Procedures, Item 1.2.15 Asphalt Full-Depth Removal

Add:

.5 This item shall also include the removal of 150mm of existing granular materials.

2. Questions and Answers

Q1: I have noticed an issue in the drawings for this tender in relation to the new Asphaltic Plug Expansion Joint. On Drawing S-101 – Repair Construction Detail, it states that the new joint is to be 760mm in width. This exceed the maximum width of 600mm that manufacturers permit for Asphaltic Plug Joints.

A1: For consistency between bidders, the Contractor should supply cost for a 760mm-wide joint.

Q2: Is the asphalt liquid indexed on the job?

A2: No, there will not be any indexing for the asphalt liquid on this project.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.