



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Sikanni Remediation & Relocation	
Solicitation No. - N° de l'invitation EZ897-170083/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2016-06-08
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7791	
File No. - N° de dossier PWY-6-39018 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-06-17	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Sikanni Maintenance Camp - km 254 Alaska Highway, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ897-170083/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
006
File No. - N° du dossier
pwy-6-39018

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Solicitation Amendment 006 is raised to extend the bid closing date, and to incorporate Questions & Answers received to date.

Extension of Time

**Sikanni Remediation & Building Relocation
– Sikanni Maintenance Camp, Alaska Highway, BC**

Solicitation No: EZ87-170083/A

Notice is hereby given that the time for reception of tenders previously due at
2:00 p.m. P.D.T. on June 13, 2016 is hereby extended to

2:00 p.m. P.D.T. on June 17, 2016.

NOTE TO BIDDERS: Use the mailing label below and affix it securely to the outside of the envelope or package containing your bid. For revisions to bids submitted by facsimile (fax # (604) 775-9381), use this sheet as the cover sheet. Always ensure your company name, return address, tender number and closing date appear legibly on the outside of your bid submission.

**REAL PROPERTY CONTRACTING
Public Works & Government Services Canada
Room 219 - 800 Burrard Street
Vancouver, B.C. V6Z 0B9**

Requisition No.: EZ897-170083/A
Tender Closing Date & Time: June 17th, 2016 @ 1400 P.D.T.
Project Description: Sikanni Remediation & Building Relocation
– Sikanni Maintenance Camp, Alaska Highway, BC

KN

Q1: Can sieve results be provided by PWGSC for the granular material proposed for use as backfill from the Sikanni Chief Maintenance yard?

A1: A sieve analysis for the Contractor's off-site supplied backfill material is not being provided. The material must meet the compaction requirements and be inspected, stamped and sealed by the Contractor's geotechnical engineer.

Q2: Also can the location of the onsite fill material be provided in a drawing? Need to determine the amount of clearing required. Need to know if there any access issues to get to material.

A2: Very minimal to no clearing or grubbing will be required. Fill material locations are generally accessible and not restricted.

Q3: Also as site meeting did not include a visit to the Man and Beast site can a drawing be provided detailing the location within the pit where the material will be derived from? The amount of clearing/grubbing required at the man and beast pit? Are there any piles to be moved at the man and beast pit?

A3: Clearing and grubbing is not required to access material and piles are not required to be moved. Material will be accessed from existing stockpiles.

Q4: Will non-potable water be made available from a PWGSC pumping station at the Sikanni River?

A4: Water will not be provided by PWGSC.

Q5: Section 31 23 33.01 paragraph 1.4.6 indicates that all backfill is provided "free of charge" from the Site and the Man and Beast Pit, however, cost item 15 in the Base Work, and 17 in the Optional Work indicate "procurement" is required. Please clarify.

A5: Section 31 23.33.01 3.8 details the three types of backfill. The procurement in line items noted are for off-site imported material supplied by the Contractor.

Q6: Section 31 23 33.01, paragraph part 2 3.3.3. indicates that TSS analysis is not required, however, treatment is required. Please confirm if analysis of TSS is required prior to discharge.

A6: Section 01 35 13.43 1.8 details the testing requirements. The section noted details the comparison of results to guidelines, where applicable. TSS analysis must be conducted and <100mg/L as detailed in Section 03 35 13.43 1.8.4.

Q7: Section 02 61 00 paragraph Part 2 - 2.1.4 states that the maximum stockpile height is 2.0 m. Based on the biocell dimensions in Drawing 3, and volume estimates, the biocell will exceed 2.0 m in height. Please confirm that this is acceptable.

A7: The intent is that the soil is spread evenly across the biocell, not mounded and at least level with the berms to facilitate drainage.

Q8: Please provide excavation detail on cross sections Drawing 5 and 6.

A8: Section 31 23 33.01 1.7 excavation designs are required submittals by the Contractor.

Q9: Please provide remedial excavation contours on Drawing 4 so that steep slopes are identified. Please confirm that excavation support is not required.

A9: Section 31 23 33.01 1.7 excavation designs are required submittals by the Contractor.

Q10: Does the remedial excavation extend to bedrock? If so, does the bedrock surface need cleaning? If so – what methods are acceptable?

A10: If bedrock is encountered during the excavation, excavator scraping to remove soil and as accepted by the Departmental Representative.

Q11: Section 02 61 00.01 indicates that water cannot be discharged from the treatment system until laboratory results indicate adequate treatment of each separate batch. Once the system performance is confirmed by lab results of the initial batch, can continuous discharge occur with intermittent monitoring? If so – how often would monitoring samples be required?

A11: Section 01 35 13.43 1.9.8 follow-up sampling to confirm treated water quality is at the discretion of the Departmental Representative and will be dependent on volume of water treated.

Q12: Can you please confirm that the superintendent / Field Coordinator #2 has to be a direct employee of the bidding entity and not a subcontractor?

A12.) The superintendent / Field Coordinator #2 can be either a direct employee of the bidding entity or a subcontractor.

Q13: Is the tender winning contractor required to add PWGSC as Additional Insured with respect to the contractors Fixed Site Pollution Liability policy or is PWGSC requesting that the contractor place Fixed Site Pollution Liability insurance on the project site for the duration of the project or a 12 month period?

A13: Please refer to page 2 of Annex A – Certificate of Insurance in the Invitation To Tender document.

All other terms and conditions remain unchanged.