



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Safety Improvements Road Construction, Hwy 93S, Kootenay National Park (Km 55.8-76.6)		
Solicitation No.: / N° de l'invitation : 5P420-16-5071/A	Amendment No.: / N° de modification de l'invitation : 005	Date: June 9, 2016 Date : 9 juin 2016
GETS Reference No.: / N° de référence de SEAG : PW-16-00733061		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: June 14, 2016	Time Zone: Mountain Daylight Time (MDT)
À : 14h00	Le : 14 juin 2016	Fuseau horaire : Heure avancée des Rocheuses (HAR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 005

This amendment is being raised to amend the following submitted documents and to respond to questions submitted in response to solicitation 5P420-16-5071/A:

A. REFERENCE DOCUMENTS

The amended Tender Specification sheets for this project is attached to amend and replace the following sheet numbers: 4, 7, 44, 54, 86, 120, 122, 155 and 158

B. QUESTIONS AND ANSWERS

Q2. There are no bid items for line painting or rumble strips. Please confirm that these items are by others for km 55.8-76.6.

A2. Yes, there are no line items for these items due to there being a deferred overlay. The rumble strips are shown in the drawings as Not in Contract (NIC) as a reference. Paint is included as part of the Prime Cost Sum (PCS).

Q3. Please confirm location that Asphalt plant can be setup for km 55.8-76.6.

A3. Asphalt plant setup for km 55.8-76.6 shall be placed at Settler's Pit.

Q4. Please confirm Laydown and site office location for km 55.8-76.6.

A4. Laydown and site office for km 55.8-76.6 shall be 4 Mile Pit (Hector Pit).

Q5. In regards to item 12.a – Supply of barriers, can you confirm what pit these barriers are to be delivered and stockpiled in.

A5. Mannix Pit.

Q6. In regards to item 12.b – Removal of barriers, can you confirm what pit these barriers are to be removed and stockpiled in?

A6. Mannix Pit.

Q7. Would you be able to provide the volumes per station in an Excel format for this project?

A7. No.

C. REVISIONS TO SPECIFICATIONS

Section 31 71 13.01 Precast Concrete Barrier Part 1, General 1.1.1 & Part 2, 2.1 Material states "In addition, all end faces to have 25 mm chamfered edges." This statement will be removed for the contract for Hwy 93S Safety Improvements km 56-77.

All other terms and conditions remain the same.