



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Sikanni Remediation & Relocation	
Solicitation No. - N° de l'invitation EZ897-170083/A	Amendment No. - N° modif. 008
Client Reference No. - N° de référence du client	Date 2016-06-14
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7791	
File No. - N° de dossier PWY-6-39018 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-06-17	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Sikanni Maintenance Camp - km 254 Alaska Highway, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ897-170083/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
008
File No. - N° du dossier
pwy-6-39018

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

This Solicitation Amendment 008 is raised to incorporate Questions & Answers received.

Q1: With respect to Summary of Work 1.3.23, please confirm the scope of shop building electrical systems upgrades required with respect to building life safety system upgrades?

A1: The information is located in the electrical section General Provisions 16010 in Appendix D.

Q2: Please provide the current configuration of the existing site trailers and load demands for temporary power purposes.

A2: PWGSC is unable to provide current configuration of the trailers. The load demand for temporary power is 100 amps.

Q3: Are there any details showing the existing underground conduit routing?

A3: No, there are no underground electrical conduits at the site.

Q4: Where is the incoming power feed and transformer location?

A4: The site is powered by a generator, so there is no incoming power feed or transformer.

All other terms and conditions remain unchanged.