



ADDENDUM # 1

Solicitation Number: 16-2023

Title: 16-2023 INSPECTION AND TESTING OF THE FIRE ALARM SYSTEMS

Date: June 13, 2016

The following supplements and/or supersedes the Invitation to Tender documents issued on April 27, 2016. This addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. Any change to the cost of the work as a result of this addendum is to be included in the price proposal. The following revisions supersede the information contained in the original Invitation to Tender Package for the above-mentioned project to the extent referenced and shall become part thereof.

Q & A

Q1 Is the fire alarm system in Building 21 addressable, conventional or a combination?

A1 The system in Building 21 is a combination of addressable and conventional.

Q2 Does Building 22 have devices in confined spaces?

A2 Yes, there are devices in crawl spaces in building 22.

Q3 When is the annual testing conducted?

A3 The annual testing is done in August.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

End of Addendum #1