Addendum/Addenda

Project Description / Description de projet M-36 modernization of Passenger Elevator, Montreal Road Campus - Ottawa			
Solicitation No./ N° de sollicitation RFP 16-22031	Project No./N° de projet M36-5217		W.O. No./Nº d'ordre de travail
Departmental Representative / Représentant Ministériel Mark O'Connor	Date June 16, 2016		
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.	

This Addendum is issued in response to the following questions.

General Conditions

- Section 37.2- Delete
- Section 43.3- Delete
- Section 50.1.1, 3rd line, insert "negligent" before "performance".

Appendix "E"

- Section GC11, 1st line, delete "Named".
- Sections 2.7 & CGL3, delete.
- Sections BR1 & BR2.2.2, delete.
- Section BR7, delete.

No changes to the above specification sections will be entertained

Section 00 01 10

- Section 3.1- Completion Change Completion of work from 20 weeks to READ 24 weeks
- Section 12.1 NRC Operation staff Normal working hours are 8:00 am to 4:30 pm
- Section 12.4 Cost per hour if escort is required, for a Commissionaire \$25.00/hour. Minimum 4 hour charge
- Section 16 -No need for Mock ups, samples for cab interior and fixtures will be acceptable to NRC
- Section 27.4 Responsibility of the Project General Contractor





The following sections will be responsibility of the Project general Contractor as they are applicable in the performance to the scope of work:

- Section 19
- Section 24
- Section 32
- Section 37
- Section 38

Section 14 12 60

• Section 1.2 – Please provide names of Fire Alarm contractors that are familiar with the site.

Electrical Contractors with Licensed Electricians having CFAA certification and qualified with Edwards fire alarm systems should be employed to work on the respective building fire alarm system.

- Section 1.2.2.2- Full height standard barricades will be acceptable to NRC
- Section 1.11.5- We will provide TSSA required drawings only, which are <u>not</u> to scale. **This will be acceptable to NRC**.
- Section 1.17.1- Payment terms: Based on the Approved Cost Breakdown payment will be approved to work performed to the date the monthly invoice is submitted
- Section 2.11- Can car safeties be retained and refurbished ? No change to the specification will be accepted on this
- Section 2.17- Will a non propriety controller be acceptable No change to the specification will be accepted on this
- Section 2.17.4- Is Air conditioning really required in the controller ? As per the specification, Section 2.17.4
- Section 2.28- In Lieu of Avesta Deco 1, is Rimex 12LG acceptable ? No, unless the Avesta Deco 1 is NO longer available
- Section 3.3.4 No data tags where visible at time of job showing. Any Engineering assessment due to excessive weight added to elevators due to cab finishes will be the Owners responsibility.
 No change to the specification will be accepted on this

End of Addendum #1