



ADDENDUM N0: 2

DATE: June 15, 2016

TO/AU: Bidders

**Subject/Objet: Re: IP-11164 Watermain Extension Secondary Loop Area 1 Phase 4
CRC - IO # - 603385**

The purpose of this Addendum No. 1 is to provide answers to questions received and to advise bidders of certain changes to the above referenced ITT.

1. Question: Approximate linear meter of watermain to be installed?

Answer: Approximately 252 meters of 300mm Dia. Pipe.

ALL OTHER TERMS AND CONDITIONS OF THE SUBJECT ITT REMAIN UNCHANGED AND IN EFFECT

Anne Nino
Manager, Procurement and Contracting/Gestionnaire intérimaire
Centre des approvisionnements et des marchés
Communications Research Centre/Centre de recherches sur les communications
Industry Canada/Industrie Canada
Building/Immeuble 2D, Room/pièce 138
3701 Carling Avenue/3701, avenue Carling
Ottawa ON K2H 8S2
Email address/adresse courriel: Anne.Nino@canada.ca
Tel/tél: 613-998-1922
Fax/télécopieur: 613-993-8657