



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet Dredging Cape St. Mary's	
Solicitation No. - N° de l'invitation EB144-170448/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client EB144-17-0448	Date 2016-06-21
GETS Reference No. - N° de référence de SEAG PW-\$PWA-124-5410	
File No. - N° de dossier PWA-6-76022 (124)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-06-30	
Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Matheson (PWA), Valerie	Buyer Id - Id de l'acheteur pwa124
Telephone No. - N° de téléphone (902) 496-5100 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EB144-170448/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
PWA124

Client Ref. No. - N° de réf. du client
EB144-17-0448

File No. - N° du dossier
PWA-6-76021

CCC No./N° CCC - FMS No/ N° VME

Amendment 001

Amendment 001 is raised to answer questions received following the release of Solicitation EB144-170448

Q: The dredge disposal at the end of the wharf....is that where we can pump the material?

A: Yes, the material can be pumped to the Dredge Disposal cell located on site which is indicated on Sheet 1 of 3 of the Civil Drawings. The "Service Area, Dredge Disposal" identified on this Plan has an available volume of 16,000 cubic metres.

Q: What kind of tide's do we have to deal with...is this in the Bay of Fundy?

A: H.N.T. (*Highest Normal Tide*) is +5.2m. This site is located on the Bay of Fundy.

Q: Who would the contact person be for a site visit?

A: As stated in item **SI03 SITE VISIT** of the Solicitation document –

"Bidders may view the site without appointment as it is a publicly accessible site."

All other terms and conditions remain the same.