



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions
- TPSGC**

11 Laurier St. / 11, rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

Bid Fax: (819) 997-9776

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Vehicles & Industrial Products Division

11 Laurier St./11, rue Laurier

7A2, Place du Portage, Phase III

Gatineau, Québec K1A 0S5

Title - Sujet BLDG. 2E - AIR HANDLING UNIT	
Solicitation No. - N° de l'invitation U6800-164722/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client U6800-164722	Date 2016-06-21
GETS Reference No. - N° de référence de SEAG PW-\$\$HP-912-71015	
File No. - N° de dossier hp912.U6800-164722	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-07-11	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Pearson, Neil	Buyer Id - Id de l'acheteur hp912
Telephone No. - N° de téléphone (873) 469-3312 ()	FAX No. - N° de FAX (819) 953-2953
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This solicitation amendment is raised to address bidders questions.

Question 1

1.12.8 - Products – there is no new curb on this project please clarify

Answer:

Para 1.12.8 Existing roof curb shall be utilized, new HVAC unit frame shall be constructed to fit existing curb.

Question 2

1.13.2 – Cabinet – I believe the checker plate should be 14ga only (not 16ga) please clarify

Answer:

Para 1.13.2 Checker plate around HVAC unit cabinet shall be 14 ga

Question 3

1.13.11 – Cabinet - I believe the checker plate should be 14ga only (not 16ga) please clarify

Answer:

Para 1.13.11 Checker plate around HVAC unit cabinet shall be 14 ga

Question 4

1.15.4 – Filters – In order to meet dimensions I require the final filters to be 4” instead of 6” deep – MERV14

Answer:

Para 1.15.4 Final filters shall be 100mm MERV14

Question 5

1.19.1.a – Controls – Is this for monitor only or for full control thru BACnet? Is BACnet sending temperature reset, damper and vfd reset signals?

- It also states that the unit should be stand alone, but if controlled (reset signals) it would not be a true stand-alone unit.

- If BACnet controlled, and the BACnet goes down for some reason our unit will still operate at the last command (flash memory) – is this ok?

Answer

Para 1.19.1 Unit to have an integral controller which will communicate with the BACnet controller by others. The unit controller shall accept a temperature, vfd and damper resets thru BACnet.

Question 6

1.23.3.d – Installation Assistance – Is it really required to allow for one year maintenance? We are not a service company and would suggest that this gets put into the tender package for the installation.

Answer:

One year is not required. We request four eight hour site visits to assist with installation.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME