



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet CFIA Dartmouth Lab Renovations	
Solicitation No. - N° de l'invitation 39903-170139/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client 39903-17-0139	Date 2016-06-22
GETS Reference No. - N° de référence de SEAG PW-\$PWA-122-5405	
File No. - N° de dossier PWA-6-76016 (122)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-06-29	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Chinye (PWA), Chukwudi	Buyer Id - Id de l'acheteur pwa122
Telephone No. - N° de téléphone (902) 496-5476 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Due to the technical nature of this amendment, it will be available in ENGLISH Only.

Amendment 003 is raised to answer the questions and incorporate the changes below:

Question 1: Section 07 54 19 – Polyvinyl-chloride Roofing: Specs calls for 1% slope using ISO with ship lapped edges. Roof assemblies R1 and R2 calls for tapered insulation with a base layer of 4". How should we proceed with this? Do we need to have a constant perimeter?

Answer to question 1: Maintain a constant perimeter at +175, or as indicated on Drawing. A2.3 - Roof Plan.

Question 2: Section 32 14 13 – Precast Concrete Pavers: Seeking clarification as to how the precast stair was to be produced. For example, a single cast unit or individual riser slabs. Are there any detailed sketches available?

Answer to question 2: Precast concrete steps are specified as Individual 1200 x 400 x 152 mm H. treads (riser slabs). No detailed sketches have been issued.

STRUCTURAL SPECIFICATIONS:

1. SECTION 05 12 23 – STRUCTURAL STEEL FOR BUILDINGS

- .1 Delete items 2.3 & 2.4.

ARCHITECTURAL DRAWINGS:

1. DRAWING A1.2 – PART SITE PLAN

- .1 SECTION 3.A1.2 – EMERGENCY GENERATOR:
 - .1 On left side of the section, revise slab thickness from 350 to 450 mm thick. On right side of section, revise slab thickness from 250 to 350 mm thick and height of concrete curb (from underside of slab) from 500 to 520 mm.

STRUCTURAL DRAWINGS:

.1 DRAWING S1.0 – GENERATOR PAD PLAN AND SECTIONS

- .1 SECTION 1A:
 - .2 On left and right sides of the section, revise vertical dimensions of 1210 to 1310 and 350 to 450. In the middle of the section, revise vertical dimension of 450 to 550.
- .2 SECTION 1B:
 - .1 On left and right sides of the section, revise vertical dimensions of 1210 to 1310 and 350 to 450.

DRAWING S1.1 – GENERATOR PAD SECTIONS & DETAILS

- .1 SECTION 11A:
 - .1 On left side of the section, revise vertical dimensions of 1210 to 1310 and 420 to 520. On right side of the section, revise vertical dimensions of 1210 to 1310 and 350 to 450.
- .2 SECTION 11B:
 - .1 On left side of the section, revise vertical dimensions of 1210 to 1310 and 250 to 350. On right side of the section, revise vertical dimensions of 1210 to 1310 and 350 to 450.

2. DRAWING S2.0 – LOADING DOCK CANOPY PLANS AND DETAILS

- .1 STEEL PLAN:
 - .1 Add note - "NOTE: ALL STEEL IN CANOPY SHALL BE HOT DIP GALVANIZED."

3. **DRAWING S2.1 – LOADING DOCK CANOPY SECTIONS AND DETAILS**

- .1 Remove all references to “new sleeves” and or “new sleeve assemblies” and replace with note - “NOTE: EXCAVATE AROUND EXISTING PIPES, TAKING CARE NOT TO DISTURB THEM. PLACE ENGINEERED FILL AROUND EXISTING PIPES. IF THE EXISTING PIPES ARE AFFECTED BY THE NEW CONSTRUCTION WORK, NOTIFY THE DEPARTMENTAL REPRESENTATIVE IMMEDIATELY.”

All Other Terms and Conditions Remain the Same.