



Materiel and Procurement Services
200 Kent Street, Station 9W079
Ottawa, Ontario
K1A 0E6

FP802-160065

June 21, 2016

Subject: Invitation to Tender: FP802-160065

Title: Cathodic Protection Works

Work site location: Rivière-au-Renard, North Gaspésie region, Qc

ADDENDUM: NO. 03

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#03) is hereby issued.

Department of Fisheries and Oceans

Bid Closing Date: Thursday, June 23, 2016
Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)
RFP File No: FP802-160065

QUESTIONS and ANSWERS

1. Question from Bidder:

In Specs, Section 26 42 30, art. 2.2 and art 2.6.4.1, it is written: "The anode-electrical conductor splice is ensured by a mechanical connection and silver welding." Should we make a mechanical connection OR silver welding?

DFO Answer 01:

Mechanical connection AND silver welding.

2. Question from Bidder:

In Specs, Section 26 42 30, art. 2.6.4.3, What do you mean by epoxy grout?

DFO Answer 02:

Fill space of the anodes holder where the splice is with epoxy grout.



3. Question from Bidder:

In the same Section of Specs, art. 2.7.2.1, we shall provide 10 breakers. Would it be possible to know the type of breakers and positioning?

DFO Answer 03:

It's only a junction box with a splice.

All other Terms and Conditions for this requirement remain unchanged.

Yours truly,

Lynda Coulombe

Senior Procurement Officer

Tel: (613) 993-2839

E-mail: Lynda.Coulombe@dfo-mpo.gc.ca