



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada

Place Bonaventure, portail Sud-Est

800, rue de La Gauchetière Ouest

7^{ème} étage

Montréal

Québec

H5A 1L6

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Travaux publics et Services gouvernementaux Canada

Place Bonaventure, portail Sud-Est

800, rue de La Gauchetière Ouest

7^{ème} étage

Montréal

Québec

H5A 1L6

Title - Sujet Reno.chauffage refroid. Lennoxville	
Solicitation No. - N° de l'invitation EF944-170110/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.078727.001	Date 2016-06-23
GETS Reference No. - N° de référence de SEAG PW-\$MTC-255-13864	
File No. - N° de dossier MTC-6-39029 (255)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-06-30	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Desforges, Julie	Buyer Id - Id de l'acheteur mtc255
Telephone No. - N° de téléphone (514) 496-3413 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EF944-170110/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
mtc255

Client Ref. No. - N° de réf. du client
R.078727.001

File No. - N° du dossier
MTC-6-39029

CCC No./N° CCC - FMS No./N° VME

THE INVITATION TO TENDER IS MODIFIED AS MENTIONED BELOW:

Addendum 4

Please find enclosed herewith the above-mentioned addendum which forms part of the tender documents.

Questions and answers related to this invitation to tender:

Question 20:

As part of the project Research and Development Centre in Sherbrooke, we want to know if it was possible to suggest an equivalence to the enthalpy wheel? We offer NOVELAIRE mark.

Answer 20:

The proposed product is accepted provided that it can be installed and mounted on site without removing the walls of the ventilation unit as for the unit specified. The product must meet all performance criterias in specifications.

Question 21:

In the ventilation scope of work section 23 23 00 - Refrigerated Networks - piping. While coolers are provided by the plumbing contractor / heating. It must also fill the coolant system. This means that the plumber install the chillers, the contractor provided ventilation and install the refrigerant piping and the plumber completes the refrigerant system. Would it not be more appropriate that the plumber also performs its refrigerant piping for equipment it provides?

Answer 21:

See addendum M2

Question 22:

Please correct the extent of ventilation work for the supply and installation of flue piping.

Answer 22:

See addendum M2

Question 23:

Here is a selection for a Ventrol heating coil that we propose as per equity method. Is this product accepted?

Answer 22:

Yes, provided that the coils submitted shop drawings meet the performance criteria in specifications (thickness, size, materials, capacities, etc.).

Solicitation No. - N° de l'invitation
EF944-170110/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
mtc255

Client Ref. No. - N° de réf. du client
R.078727.001

File No. - N° du dossier
MTC-6-39029

CCC No./N° CCC - FMS No./N° VME

Question 24:

As requested in the instructions to tenderers, here is the selection of the enthalpy wheel we offer equity method from that specified (section 23 33 00 2-3-4 pages): masters ECW786

Answer 24:

The proposed product is accepted provided that it can be installed and mounted on site without removing the walls of the ventilation unit as for the unit specified. The product must meet all performance criterias in specifications.

All other terms, clauses and conditions remain unchanged.