



Materiel and Procurement Services  
200 Kent Street, Station 9W079  
Ottawa, Ontario  
K1A 0E6

**FP802-160059**

**June 24, 2016**

**Subject:** Invitation to Tender: FP802-160059  
**Title:** Electrical Improvements  
**Work site location:** Southern Harbour (Bests Cove), NL

**ADDENDUM: NO. 01**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#01) is hereby issued.

**Department of Fisheries and Oceans**

**Bid Closing Date: Tuesday, July 5, 2016**  
**Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)**  
**RFP File No: FP802-160059**

---

## QUESTIONS and ANSWERS

**1. Question from Bidder:**

The drawing makes reference to a junction box or junction boxes.

**DFO Answer 01:**

Drawing E1 references 2 manholes.

**2. Question from Bidder:**

Can you provide more detail and additional info as to what size , type of material , etc and the location of Proposed Junction Boxes for this project



**DFO Answer 02:**

Manholes are detailed on drawing A1 (Manhole (Electrical Pull Pit)). Location of manholes is covered in note 3: Manholes to be within property boundary. Contractor to provide surveyor whom is to confirm and document boundary prior to placement of manholes. Owner will provide legal survey.

**All other Terms and Conditions for this requirement remain unchanged.**

Yours truly,

**Lynda Coulombe**

Senior Procurement Officer

Tel: (613) 993-2839

E-mail: [Lynda.Coulombe@dfo-mpo.gc.ca](mailto:Lynda.Coulombe@dfo-mpo.gc.ca)