

PART 1 - GENERAL

1.1 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Shop drawings; submit drawings stamped and signed by professional engineer registered or licensed in one of the Provinces of Canada.
  - .3 Shop drawings to show:
    - .1 Mounting arrangements.
    - .2 Operating and maintenance clearances.
  - .4 Shop drawings and product data accompanied by:
    - .1 Detailed drawings of bases, supports, and anchor bolts.
    - .2 Acoustical sound power data, where applicable.
    - .3 Points of operation on performance curves.
    - .4 Manufacturer to certify current model production.
    - .5 Certification of compliance to applicable codes.
  - .5 Closeout Submittals:
    - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
    - .2 Operation and maintenance manual approved by, and final copies deposited with, Departmental Representative before final inspection.
    - .3 Operation data to include:
      - .1 Control schematics for systems including environmental controls.
      - .2 Description of systems and their controls.
      - .3 Description of operation of systems at various loads together with reset schedules and seasonal variances.
      - .4 Operation instruction for systems and component.
      - .5 Description of actions to be taken in event of equipment failure.
      - .6 Valves schedule and flow diagram.
      - .7 Colour coding chart.
    - .4 Maintenance data to include:
      - .1 Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
      - .2 Data to include schedules of tasks, frequency, tools required and task time.
-

- |                            |             |
|----------------------------|-------------|
| 1.1 SUBMITTALS<br>(Cont'd) | .5 (Cont'd) |
|----------------------------|-------------|
- 
- .4 (Cont'd)
  - .5 Performance data to include:
    - .1 Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
    - .2 Equipment performance verification test results.
    - .3 Special performance data as specified.
    - .4 Testing, adjusting and balancing reports as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
  - .6 Approvals:
    - .1 Submit 2 copies of draft Operation and Maintenance Manual to Departmental Representative for approval. Submission of individual data will not be accepted unless directed by Departmental Representative.
    - .2 Make changes as required and re-submit as directed by Departmental Representative.
  - .7 Additional data:
    - .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
  - .8 Site records:
    - .1 Departmental Representative will provide 1 set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
    - .2 Transfer information weekly to reproducibles, revising reproducibles to show work as actually installed.
    - .3 Use different colour waterproof ink for each service.
    - .4 Make available for reference purposes and inspection.
  - .9 As-built drawings:
    - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
-

- |  |             |  |
|--|-------------|--|
| <u>1.1 SUBMITTALS</u><br><u>(Cont'd)</u> | .5 (Cont'd) |  |
|  | .9 (Cont'd) |  |
|  | .2          | Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date). |
|  | .3          | Submit to Departmental Representative for approval and make corrections as directed.   |
|  | .4          | Perform testing, adjusting and balancing for HVAC using as-built drawings.   |
|  | .5          | Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.  |
|  | .10         | Submit copies of as-built drawings for inclusion in final TAB report.  |
| <u>1.2 QUALITY ASSURANCE</u>             | .1          | Quality Assurance: in accordance with Section 01 45 00 - Quality Control.  |
| <u>1.3 MAINTENANCE</u>                   | .1          | Furnish spare parts in accordance with Section 01 78 00 - Closeout Submittals as follows:  |
|  | .1          | One set of packing for each pump.  |
|  | .2          | One casing joint gasket for each size pump.  |
|  | .3          | One head gasket set for each heat exchanger.   |
|  | .4          | One glass for each gauge glass.  |
|  | .5          | One filter cartridge or set of filter media for each filter or filter bank in addition to final operating set.   |
|  | .2          | Provide one set of special tools required to service equipment as recommended by manufacturers and in accordance with Section 01 78 00 - Closeout Submittals.  |
|  | .3          | Furnish one commercial quality grease gun, grease and adapters to suit different types of grease and grease fittings.  |

PART 3 - EXECUTION

- |   |    |   |
|---|----|---|
| <u>3.1 PAINTING<br/>REPAIRS AND<br/>RESTORATION</u> | .1 | Prime and touch up marred finished paintwork to match original.   |
|   | .2 | Restore to new condition, finishes which have been damaged.   |
| <u>3.2 CLEANING</u>                                 | .1 | Clean interior and exterior of all systems including strainers. Vacuum interior of ductwork and air handling units.   |
| <u>3.3 DEMONSTRATION</u>                            | .1 | Departmental Representative will use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.  |
|   | .2 | Trial usage to apply to following equipment and systems:<br>.1 Energy Recovery Ventilator (ERV).<br>.2 Mini split system.   |
|   | .3 | Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance. |
|   | .4 | Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.  |
| <u>3.4 PROTECTION</u>                               | .1 | Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.   |

PART 1 - GENERAL

- |                       |    |  |
|-----------------------|----|--|
| <u>1.1 Summary</u>    | .1 | Section Includes:<br>.1 Thermal insulation for piping and piping accessories in commercial type application.<br>.2 Sustainable requirements for construction and verification.   |
| <u>1.2 References</u> | .1 | American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)<br>.1 ASHRAE Standard 90.1, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA co-spondored; ANSI approved; Continuous Maintenance Standard).   |
|                       | .2 | American Society for Testing and Materials (ASTM)<br>.1 ASTM C335-04, Standard for Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.<br>.2 ASTM C547-2003, Mineral Fiber Pipe Insulation.   |
|                       | .3 | Canadian General Standards Board (CGSB)<br>.1 CGSB 51-GP-52Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.<br>.2 CAN/CGSB-51.53-95, Poly (Vinyl Chloride) Jacketting Sheet, for Insulated Pipes, Vessels and Round Ducts.   |
|                       | .4 | Health Canada/Workplace Hazardous Materials Information System (WHMIS)<br>.1 Material Safety Data Sheets (MSDS).   |
|                       | .5 | Manufacturer's Trade Associations<br>.1 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (Revised 2004).   |
|                       | .6 | Underwriters' Laboratories of Canada (ULC)<br>.1 CAN/ULC-S102-10, Surface Burning Characteristics of Building Materials and Assemblies.<br>.2 CAN/ULC-S701-05, Thermal Insulation, Polystyrene, Boards and Pipe Covering.<br>.3 CAN/ULC-S702-09, Thermal Insulation, Mineral Fibre, for Buildings.<br>.4 CAN/ULC-S702.2-03, Thermal Insulation, Mineral Fibre for Buildings, Part 2: Application Guidelines. |
-

- 1.3 Definitions
- .1 For purposes of this section:
    - .1 "CONCEALED" - insulated mechanical services in suspended ceilings and non-accessible chases and furred-in spaces.
    - .2 "EXPOSED" - will mean "not concealed" as defined herein.
  - .2 TIAC ss:
    - .1 CRF: Code Rectangular Finish.
    - .2 CPF: Code Piping Finish.

PART 2 - PRODUCTS

- 2.1 Fire and Smoke Rating
- .1 In accordance with CAN/ULC-S102.
    - .1 Maximum flame spread rating: 25.
    - .2 Maximum smoke developed rating: 50.
- 2.2 Insulation
- .1 Mineral fibre specified includes glass fibre, rock wool, slag wool.
  - .2 Thermal conductivity ("k" factor) not to exceed specified values at 24°C mean temperature when tested in accordance with ASTM C335.
  - .3 TIAC Code A-1: Rigid moulded mineral fibre without factory applied vapour retarder jacket.
    - .1 Mineral fibre: to CAN/ULC-S702.
    - .2 Maximum "k" factor: to CAN/ULC-S702.
  - .4 TIAC Code A-3: Rigid moulded mineral fibre with factory applied vapour retarder jacket.
    - .1 Mineral fibre: to CAN/ULC-S702.
    - .2 Jacket: to CGSB 51-GP-52Ma.
    - .3 Maximum "k" factor: to CAN/ULC-S702.
  - .5 TIAC Code A-6: Flexible unicellular tubular elastomer.
    - .1 Insulation: with vapour retarder jacket.
    - .2 Jacket: to CGSB 51-GP-52Ma.
    - .3 Certified by manufacturer: free of potential stress corrosion cracking corrodants.
- 2.3 Insulation Securement
- .1 Tape: Self-adhesive, aluminum, plain, 50 mm wide minimum.
-

- |   |    |   |
|---|----|---|
| <u>2.3 Insulation Securement (Cont'd)</u> | .2 | Contact adhesive: Quick setting.  |
|   | .3 | Canvas adhesive: Washable.  |
|   | .4 | Tie wire: 1.5 mm diameter stainless steel.  |
| <u>2.4 Cement</u>                         | .1 | Thermal insulating and finishing cement:<br>.1 Hydraulic setting or Air drying on mineral wool, to ASTM C 449/C449M.  |
| <u>2.5 Vapour Retarder Lap Adhesive</u>   | .1 | Water based, fire retardant type, compatible with insulation.   |
| <u>2.6 Indoor Vapour Retarder Finish</u>  | .1 | Vinyl emulsion type acrylic, compatible with insulation.  |
| <u>2.7 Jackets</u>                        | .1 | Polyvinyl Chloride (PVC):<br>.1 One-piece moulded type and sheet to CAN/CGSB-51.53 with pre-formed shapes as required.<br>.2 Colours: white.<br>.3 Minimum service temperatures: -20°C.<br>.4 Maximum service temperature: 65°C.<br>.5 Moisture vapour transmission: 0.02 perm.<br>.6 Thickness: 0.3 mm minimum.<br>.7 Fastenings:<br>.1 Use solvent weld adhesive compatible with insulation to seal laps and joints.<br>.2 Tacks.<br>.3 Pressure sensitive vinyl tape of matching colour. |

### PART 3 - EXECUTION

- |  |    |   |
|--|----|---|
| <u>3.1 Manufacturer's Instructions</u> | .1 | Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions and datasheet. |
|--|----|---|
-

3.2 Pre-Installation Requirement .1 Pressure testing of piping systems and adjacent equipment to be complete, witnessed and certified.

.2 Surfaces to be clean, dry, free from foreign material.

3.3 Installation .1 Install in accordance with TIAC National Standards.

.2 Apply materials in accordance with manufacturer's instructions and this specification.

.3 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.

.1 Install hangers, supports outside vapour retarder jacket.

.4 Supports, Hangers:

.1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.

3.4 Piping Insulation Schedules .1 Includes valves, valve bonnets, strainers, flanges and fittings unless otherwise specified.

.2 TIAC Code: A-1.

.1 Securements: Tape at 300 mm on centre.

.2 Seals: lap seal adhesive, lagging adhesive.

.3 Installation: TIAC Code 1501-H.

.3 TIAC Code: A-3.

.1 Securements: Tape at 300 mm on centre.

.2 Seals: VR lap seal adhesive, VR lagging adhesive.

.3 Installation: TIAC Code: 1501-C.

.4 Thickness of insulation to be as listed in following table.

.1 Run-outs to individual units and equipment not exceeding 4000 mm long.

.2 Do not insulate exposed runouts to plumbing fixtures, chrome plated piping, valves, fittings.

---



3.4 Piping		.4 (Cont'd)						
Applic	Temp°	TIAC	Pipe sizes (NPS) and insulation thickness					
ation	C	code	(mm)					
Run	to 1	1 1/4	2 1/2					
out		to 2	to 4		over			
Domestic		A- 1	25	25	25	38	38	38
HWS								
Domestic		A- 3	25	25	25	25	25	25
CWS								

- .5 Finishes:
- .1 Exposed PVC jacket.
- .2 Concealed, indoors: canvas on valves, fittings. No further finish.
- .3 Use vapour retarder jacket on TIAC code A-3 insulation compatible with insulation.
- .4 Finish attachments: SS screws bands, at 150 mm oc. Seals: wing closed.
- .5 Installation: To appropriate TIAC code CRF/1 through CPF/5.

Section 01 47 17 - Sustainable Requirements:  
Contractor's Verification include:

- .1 Materials and resources.
- .2 Storage and collection of recyclables.
- .3 Construction waste management.
- .4 Resource reuse.
- .5 Recycled content.
- .6 Local/regional materials.
- .7 Certified wood.
- .8 Low-emitting materials.

Cleaning.

- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.